


SiD MDI Issues

Tom Markiewicz/SLAC
SiD Collaboration Meeting
09 April 2007





Pre-Push Pull, 20mrad crossing angle, L*=3.5m Final Doublet Support and Access Plan

- One cryostat with radial step support tube with corresponding step
- Cryostat step @ z=4.8m: door can open 2m; radii from BNL

Theta	OD1	OD2
14 mrad	290mm	477mm
20mrad	305mm	512mm


May 7, 2006

- Tube cantilevered from removable base just behind closed end cap door
- Full coverage endcap Ecal/Hcal @ r>20cm
- Forward instrumented steel return flux cut back ~10cm to clear step in cryostat when door open
- Antisolenoid cryostat begins at r=30cm
- Conic beampipe to ID of outer part of LUMICAL




20 Feb 2007 BDS mtg: Brett Parker

Concept for Force Neutral Anti-Solenoid






Force Neutral Anti-Solenoid for SiD



2007.04.09 SiD Collab-FNAL SID MDI 5 of 26




QD0 + QDEX1A + Anti-Solenoid in Cryostat



2007.04.09 SiD Collab-FNAL SiD MDI 6 of 26








Seryi Proposal: Fix QF1 @ 9.6m, L* chosen by Detector Concept: Study Collimation & Optics Sensitivity

Nominal positions near IP for push-pull



Modified positions near IP: QDEX1 moves along with QD0, QF1 and QFEX2A are fixed at z = 9.5 m and 9.6 m, respectively.

A) IP
$$\frac{L^* = 3.51 \text{ m}}{QF1}$$
 QF1

IP $\frac{L^*_{ex} = 5.5 \text{ m}}{QFEX2A}$

B) IP
$$\frac{L^* = 4.0 \text{ m}}{QD0}$$
 QF1

IP $\frac{L^*_{ex} = 5.95 \text{ m}}{QFEX2A}$


C) IP
$$\frac{L^* = 4.5 \text{ m}}{QF1}$$
 QF1


IP $\frac{L^*_{ex} = 6.3 \text{ m}}{QFEX2A}$





Incoming Beam & Extracted Beam Look OK for Each Solution


Disrupted beam loss for 250 GeV low beam power option (cs14)


















SiD Final Doublet Support and Access Plan with Push Pull @ 14mrad Crossing angle, L*=3.664m


Three concepts

- Permanent liquid He feed line from barrel to QD0 with loop large enough to allow 3m door opening
- 10cm (?) radial cutback in endcap iron yoke to allow it to pass over back end of QD0 cryostat
- Drop idea of cantilevered support tube
 - QD cryostat and FCAL package supported off rails in endcap doors
 - Rails incorporate telescoping "rail extensions" to support cryostat and FCAL when door is open
 - Is this compatible with "cutback"?

2007.04.09 SiD Collab-FNAL SID MDI 11 of 26











Plan & Elevation View of FCAL/QD0 Support




Ignore for the moment fact that I have drawn endcap ECAL/HCAL down to r=20cm and yoke at 30cm





FCAL/QD0 Supported with Door Open



SiD MDI 2007.04.09 SiD Collab-FNAL 16 of 26





Three beampipe shapes have been considered over time for SiD

- Flat at 12mm for VXD, flared to O.D. of Lumical (190mm) @ z_{min} = 1.68m of endcap ECAL
- Flat at 12mm for VXD, flared to I.D. of Lumical (86.5mm) @ z_{min} = 1.68m of endcap ECAL
- Flat at 12mm for VXD, flared rapidly to clear pair stay free until r=86.5mm (r_{min} of Lumical @ z_{min} = 1.68m), then cylindrical
- In all cases, beam pipe then becomes conic and follows inner surface of mask until beampipe



12mm Beam Pipe and VXD Detail








Often forgotten points that need discussion

- There are TWO parts to "LumiCAL" whose relative importance has yet to be studied
 - Low radius extension of endcap ECAL=Lumi1
 - Large radius part of "Beamcal" beyond region where pairs hit= Lumi2
- The very heavy forward detector and masking system (Lum1, Mask (instrumented as HCAL or not?), Lum2+Beamcal package must NOT be cantilevered off QD0 cryostat EXCEPT when the door is open

2007.04.09 SiD Collab-FNAL SID MDI 20 of 26



Elevation & Plan Views of Far-Lumi/BeamCal from SiD DOD






Conceptual Solution for R20 Mechanics is Needed

- Support points
- Bellows
- Flanges
- Alignment and adjustment features
- Vacuum features (if any) at z<7m (end of QD0 cryostat)
- Cable & Gas service routing
- Rethinking of access requirements in PUSH-PULL
 - On-beamline access for rapid repair
 - Off-beamline access for VXD or TRACKER replacement



T. Maruyama Recalculation of ALL Backgrounds for Current Layout 03 April 2007 (see BDS)


14 mrad crossing geometry in Geant 3 and FLUKA



2007.04.09 SiD Collab-FNAL SiD MDI 23 of 26





Is M2 NEEDED or NOT????




2007.04.09 SiD Collab-FNAL SID MDI 24 of 26

No M2 Mask Needed









http://www-conf.slac.stanford.edu/ireng07/

Workshop on ILC Interaction Region Engineering Design

SLAC, September 17-21, 2007 (tentative)

Goal

To review and advance the design of the subsystem of the Interaction Region of ILC, such as

- Final focusing magnets
- Forward instrumentation
- Detector central regions
- IR vacuum chambers
- Cryogenic systems
- Supports for magnets and detectors
- Shielding
- Collider hall


focusing in particular on their integration, engineering and arrangements for push-pull operation.



Bonus Material Follows




VXD and Support Structures



2007.04.09 SiD Collab-FNAL SID MDI 28 of 26



R-Z View of the Pixel VXD



2007.04.09 SiD Collab-FNAL SID MDI 29 of 26



