

For each cryogenic plant (of two total)

Total predicted 4.5 K heat	(W)
Total predicted 4.5 K liquid production (for current leads)	(grams/sec)
Total predicted 70 K heat	(W)
Uncertainty and overcapacity (total combined) margin	
Installed power	(MW)
Cryogenic plant capacity (converted to 4.5 K equiv)	(kW)

1660
0.80
5080
1.54
1.13
3.45