

additional HX,
pumps, pipe, chiller

11.7 MW
(3,323 Ton)

Hybrid Cooling
Tower

78°F wet bulb
~25°C

85°F
~29°C

55°F
~13°C

9.6 MW
(2,718 Ton)

Heat
Exchanger

45°F
~7°C

12.8 MW
(3,628Ton)

Chiller

118°F
~48°C

58°F
~15°C

surface

Heat
Exchanger

shaft

45°F
~7°C

64°F
~18°C

To FanCoil
Unit

123°F
~51°C

63°F
~17°C

service tunnel

Skid HX

128°F
~53°C

68°F
~20°C

20°C SUPPLY

NOTE: IGNORE THE
CAPACITY FOR NOW