



# ***CFS Cost Reductions***

## ***Conventional Facilities and Siting Group***

***A. Enomoto, V. Kuchler, J. Osborne***



## *Session One - Processed Water*

- *Current RDR Design*
  - *Three Loop System for Process Water*
    - *Shaft (Surface to Tunnel Depth)*
    - *Tunnel Main Distribution*
    - *Skid Loop*
    - *20 °F DT*
  - *Two Loop System for Chilled Water*
    - *Shaft (Surface to Tunnel Depth)*
    - *Tunnel Main Distribution*
- *Project X Design Utilizes a Similar System with the Exception of the Shaft Loop Due to Near Surface Configuration*



## Global Design Effort - CFS

### SPECULATION LIST

| Priority        |    | DESCRIPTIONS & "color" legend (DRAFT Dec 11 2007)   |   | (gut-feel) Estimated Cost Savings | Hrs needed to evaluate cost impact/ (by Whom) | For items (by others) will impact CFS |
|-----------------|----|---|---|-----------------------------------|---|---------------------------------------|
|                 |    | (Gut-Feel) may <b>not</b> result to large savings   | (Gut-Feel) may result to savings. Will be evaluated? (potential cost savings TBD) |                                   |   |                                       |
|                 |    | MARC ROSS DEC 04, 2007 DIRECTION (LIST TO BE EVALUATED)   |   |                                   |   |                                       |
|                 |    | Will be evaluated By Others(HLRF), not CFS, whether high cost savings impact or not (not shaded) = Items that im Not Sure   |   |                                   |   |                                       |
| Low Priority    | 1  | Provide one high efficiency cogen power / cooling plant on site and distribute power and 33 degree F chilled water throughout the facility, remove the power generation and chilling cost from the project cost |   | TBD                               | Free (SteveK)                                 |                                       |
| High priority   | 4  | Eliminate one piping system by using process water as primary rejection for chilled water system w/#1 (using refrigerated heat pump as fancoils and standalone chillers for racks)                              |   | TBD                               | 40 Hrs (Emil)                                 |                                       |
|                 | 4b | Eliminate one piping system by using process water as primary rejection for chilled water system w/#1 (using process cooled fancoils), warmer tunnel (item 6_15)  |   | TBD                               | 40 Hrs (Emil)                                 |                                       |
| High priority   | 5  | Increase the delta T in the LCW and chilled water systems to 30 degrees, reduce flow, pipe size w/#1  |   | TBD                               | 40 Hrs (Emil)                                 |                                       |
|                 | 6  | Add a chiller on the process water side w#1   |   | TBD                               | N/A   |                                       |
|                 | 23 | Lower the temperature in the tunnel to 65 or 70 degrees to increase operating efficiency, extend equipment life, and improve operating environment w/#1   |   | TBD                               |   |                                       |
|                 | 33 | Consider use of renewable energy source for use with cogen system w/#1  |   | TBD                               |   |                                       |
|                 | 47 | Provide a cost analysis for reducing the overall cooling load by 5% and 10% w/#1  |   | TBD                               | N/A   |                                       |
|                 | 2  | Centralize the cooling system   |   | TBD                               |   |                                       |
|                 | 12 | Provide distributed cogen power / cryo (similar to #1 &2)   |   | TBD                               |   |                                       |
| Medium priority | 9  | Decentralize the 345 KV substation function w/ 18, 20, 38, & 39   |   |                                   |   |                                       |
| Medium priority | 18 | Electrically engineer the distribution system to optimize and reduce cost w/#9  |   |                                   |   |                                       |
| Medium priority | 20 | Provide connection to electrical utility sytem at all shafts (w/ #9)  |   |                                   |   |                                       |
| Medium priority | 38 | Optimize substation spacing w/#9  |   |                                   |   |                                       |
| Medium priority | 39 | Let the electrical utility construct substations and don't include that cost in the project construction cost w/#9  |   |                                   |   |                                       |
| Low Priority    | 10 | Centralize the HVAC and reconfigure air flow from the ends  |   |                                   | Lee?  |                                       |
| Low Priority    | 34 | Pipe two chilled water coils in series, chilled water reclaim, size one for 30 degree delta T w/#10   |   |                                   | Lee?  |                                       |
|                 | 13 | Let the temperature in the tunnel go to 104 degrees F during normal operation and local cool to 85 degrees where people are (consider increased cost for more frequent replacement)                             |   | TBD                               | 40 Hrs (Emil)                                 |                                       |
|                 | 15 | Raise tunnel temperature to 103 degrees at all times (meets OSHA requirements) w/#13  |   | TBD                               | 40 Hrs (Emil)                                 |                                       |
|                 | 17 | Provide air conditioned suits for personnel working in tunnel and let the temp go higher than OSHA requirements w/#13   |   | N/A                               | N/A   |                                       |
|                 | 14 | Consider oversizing electrical cables and transformers to reduce heat   |   | TBD                               |   |                                       |
|                 | 16 | Redesign the RF loads for more optimal process water flow   |   | TBD                               | by HLRF                                       | YES                                   |
|                 | 21 | Modify top shaft HVAC to only process make up air, add blowers down shaft for recirculation   |   | TBD                               | Lee?  |                                       |
|                 | 24 | Reduce lighting level to egress limits  |   | TBD                               | Tnm?  |                                       |
|                 | 25 | Reduce water pressure drop across components, minimize head pressure  |   | TBD                               | by HLRF                                       | YES                                   |



## Global Design Effort - CFS

### SPECULATION LIST

|               |      |  |                |                  |     |
|---------------|------|--|----------------|------------------|-----|
| High priority | 28   | Examine possibility of going to 2 condenser water loops instead of 3 as presently planned                          | N/A            | N/A              |     |
| High priority | 35a  | Consider using low mineral content water instead of LCW w/28 (design water system for low mineral water)           | TBD            | 40 Hrs (use A/E) |     |
| High priority | 31   | Allow different types of pipe materials: PVC, CPVC, HDPE, carbon fiber wrapped PE, etc in lieu of stainless steel  | Medium         | 40 Hrs (Emil)    |     |
|               | 36   | Consider replacing the fan coil units with a chilled water beam (radiant cooling)                                  |                |                  |     |
|               | 37   | Put the water piping in the concrete slab, eliminate pipe supports   |                |                  |     |
| High priority | 46   | Use water cooled waveguide in the accelerator tunnel in lieu of air cooling  | TBD            | by HLRF          | YES |
|               | 48   | Provide passive convection tunnel using cooling shafts during colder months  |                |                  |     |
|               | 49   | Provide multiple modes of operation dependent on outdoor temperature   |                |                  |     |
| High priority | 50   | Develop loads that do not require low conductivity water   | TBD            | by HLRF          | YES |
| High priority | 54   | Use the waveguide pressurization system for cooling the waveguide (flow cooled gas inside the waveguide)           | TBD            | by HLRF          | YES |
| Low Priority  | 3    | Pulse the power source for selected loads when not being used  | N/A            | N/A              |     |
|               | 7    | Use pressure regulators to control the hydrostatic pressure in the collectors                                      | N/A            | N/A              |     |
|               | 8    | Define the maximum hydrostatic pressure for the collectors   | TBD            | by HLRF          | YES |
|               | 11   | Consider expandability of systems - modular vs centralized   | N/A            | N/A              |     |
|               | 27   | Reexamine the hot changeout of modulator power supplies  | N/A            | by HLRF          |     |
|               | 29   | Plan for a 4 month downtime during the summer  | N/A            | N/A              |     |
|               | 30   | Limit the operation of the system to 72 degree wet bulb  | N/A            | N/A              |     |
|               | 40   | Use CO2/radon monitoring and limit the intake of outside air to what is necessary to maintain a safe environment   |                | Lee?             |     |
|               | 41   | Use a dessicant to dehumidify ventilation air  |                | Lee?             |     |
|               | 51   | Evaluate each load individually to determine requirements  | TBD            | by HLRF          | YES |
|               | 52   | Establish power budgets for the relay racks (400 W / RF + 10% of power supplies)                                   | TBD            | by HLRF          | YES |
|               | 53   | Provide power supply that will work with warm water if necessary (quasi militarized)                               | TBD            | by HLRF          | YES |
|               | 45   | Use on site ponds for make up water  | N/A            | N/A              |     |
|               | 55   | Consider using cooling ponds in lieu of cooling towers   | N/A            | N/A              |     |
|               | 22   | Give or sell heat from chillers to neighboring communities   | N/A            | N/A              |     |
|               | 26   | Increase the number of RF stations per LCW skids   | N/A            | N/A              |     |
|               | 32   | Use vapor phase cooling on the collector and generate electricity from excess energy                               | N/A            | N/A              |     |
|               | 42   | Use the lowest KVA transformer to reduce heat load   | N/A            | N/A              |     |
|               | 43   | Consider use of geothermal cooling   | N/A            | N/A              |     |
|               | 44   | Use the Fox river for once thru primary cooling, eliminate the cooling towers                                      | N/A            | N/A              |     |
|               | 19   | Use modular systems for all equipment  | N/A            | N/A              |     |
|               | NEW1 | Eliminate Rack Skid and replace with just pump   | under \$10M??? | 40 Hrs (Emil)    |     |
|               | NEW2 | Eliminate one piping system by using chilled water only as primary rejection, eliminate process water distribution | over \$30M???  | 40 Hrs (Emil)    |     |




## First Analysis - Eliminate Chilled Water

- **Still a Three Loop Process Water System**
- **Requires LCW Skid to Go From 20° DT to 30° DT**
- **Fan Coil Units for Service Tunnel Temperature Control Affected:**
  - Units Get Physically Larger
  - Units are Less Efficient
  - Units Operate at a Lower DT
  - Units Require More Water
  - Tunnel Temperature is 104 °F
  - > 104 °F Requires Electrical Equipment De-rating
  - > 86 °F Labor Restriction Becomes an Issue
- **Cost Impact - Reductions**
  - One Distribution System is Eliminated (Chilled Water, 2 Pipes at 8" dia)
  - Required Surface Chiller Capacity Reduced
- **Cost Impact - Neutral**
  - No Major Pumping Impact
  - No Major Electrical Impact
- **Cost Impact - Additions**
  - Process Water Pipe Size Increases from 2 @ 12" dia to 2 @ 18" dia
  - Control Racks Still Require Local Chillers for Cooling
  - Fan Coil Units get Larger



# Global Design Effort - CFS





## Second Analysis - Eliminate Process Water

- **Still a Three Loop Chilled Water System**
- **Requires LCW Skid to Go From 20° DT to 30° DT**
- **Fan Coil Units for Service Tunnel Temperature Control**
  - Remain Unchanged:**
    - **Tunnel Temperature is 86 °F**
    - **No Requirement Electrical Equipment De-rating or Labor Restrictions**
- **Cost Impact - Reductions**
  - **One Distribution System is Eliminated (Process Water, 2 Pipes at 12" dia)**
  - **Pumping Configuration Reduced**
- **Cost Impact - Neutral**
  - **Control Rack Cooling Unchanged**
  - **Fan Coil Units Unchanged**
- **Cost Impact - Additions**
  - **Chilled Water Pipe Size Increases from 2 @ 8" dia to 2 @ 10" dia**
  - **Required Surface Chiller Capacity Increased**





# Global Design Effort - CFS

## SHAFT 7 (Chilled Water Only Scheme)

12/14/2007  
E. Huedem

|                             |          |
|-----------------------------|----------|
| Total Operating Tower       | 14       |
| Each Chiller Ton            | 1333 T   |
| Total Operating Chiller Ton | 3998 T   |
| Total Operating TowerTon    | 4998 T   |
| Total Operating TowerMW     | 17.57 MW |



### BASIS

- 1 space maintain at 85 F
- 2 Load to air per RF 21.2 KW
- 3 Load to (RF) water per RF 103 KW
- 4 Racks per RF= 12 KW
- 5 Shaft 7 has 26 stations
- 6 Each Station = 4 RF
- 7 Fancoils/AC xfmr are 1 per RF but shown as 1per station for delta T sizing
- 8 Fancoil based on AAON sizing
- 9 LCW system used for now. Load based on M.Neubaer email Dec 2007, with 22 F delta T, (HLRF to refine to 30 delta T F)





## **Session Two - Underground Volume**

- **Currently Not Optimized for Equipment Size or Layout**
- **Primary Space Requirements Determined By:**
  - **Cryogenic Equipment**
  - **Process Water Equipment**
  - **HVAC Equipment**
  - **Installation and Material Handling Requirements**
- **Opportunities for Cost Reduction:**
  - **Revised Process Cooling Design May Result in a Reduction of Equipment Space Required**
  - **Revised HVAC Design May Result in a Reduction of Equipment Space Required**
  - **Overall Optimization of Equipment layout is Essential**
  - **Adjustment of Shaft Usage and Size will Affect Cavern Space Requirements**




## Session Three - Shallow Site Studies

- *Twin Tunnel Deep Solution is the RDR Base*
- *Cut and Cover Tunnel with Continuous Surface Gallery (Project X)*
- *Near Surface Tunnel with Surface Gallery Configuration (Dubna)*
- *Single Tunnel with Enclosed Exit Corridor (~7.5m dia)*
- *Single Tunnel with Fire Protected Alcoves*
- *Single Tunnel Only (LHC and XFEL)*
- *Twin Tunnel with Only One Equipment Access per Linac and Only Personnel Access Shafts at 5 km Intervals*
- *Single Tunnel with Only One Equipment Access per Linac and Only Personnel Access Shafts at 5 km Intervals*
- *Adjustments to Shaft Diameters with Respect to Material Handling*
- *Various Alternatives Noted May Preclude Construction in Certain Siting Locations*




Global Design Effort - CFS

reduce diameter of 14m shafts down to 9m Via lowering cryo






# Global Design Effort - CFS





# Global Design Effort - CFS



9m diameter shafts



## **Cost Study : reduce diameter of 14m shafts down to 9m**

- *Saving from civil engineering to reduce diameter for all six shafts would be in the region of 2Million Euros per shaft. This is only valid for the CERN deep tunnel site.*
- *This is not the case for Asia where tunnel access is via inclined tunnels rather than shafts.*
- *Extra costs due to lowering cryo magnets inclined needs to be assessed*