

KEK

Normal operation

0.2 $\mu\text{Sv/h}$ for Non-designated area

1.5 $\mu\text{Sv/h}$ for Supervised area

20 $\mu\text{Sv/h}$ for Simple controlled area

Mis-steering beam loss

1 hour integration of dose rate should not exceed 1.5 $\mu\text{Sv/h}$ using radiation monitor.

(Terminate injection and wait 1 hour)

1. mSv / week

Belle Experimental floor: Supervised area

LHC

Normal operation

0.1 $\mu\text{Sv/h}$ for Non-designated area

1 $\mu\text{Sv/h}$ for Supervised area

3 $\mu\text{Sv/h}$ for Simple controlled area

Total beam loss

0.3 mSv/h for Non-designated area

2.5 mSv/h for Supervised area

50 mSv/h for Simple controlled area

SLAC

Normal operation

0.5 $\mu\text{Sv/h}$ for GERT (General Employ Radiation Training)

5 $\mu\text{Sv/h}$ for Radiation Worker

Mis-steering

4 mSv/h

System failure

250 mSv/h and 30 mSv/event

Self-shielding detector

To evaluate strawman models

→ 250 mSv/h for total (18 MW) beam loss
(SLAC system failure)
= 14 μ Sv/h for 1 kW beam loss

GERT access (0.5 μ Sv/h) on experimental floor
Normal beam loss should be less than 36 W

Mis-steering (4 mSv/h) on experimental floor
Beam should be turn-off less than 57 sec

Beam loss


- 500 GeV, 18 MW beam loss
 - Design Goal : 250 mSv/h
- Beam loss point and material
 - Design is available :
realistic component
 - Design is not available :
pessimistic scenario, = 20 X_0 thick Cu target
- 3D Monte-Carlo simulation
- Empirical equation


Iron thickness; Yoke 280cm, Calorimeter(s) 130cm x XX%

A(Barrel Gap): **Iron 130xXX%cm**

B(Barrel) : Iron 130xXX%cm+280xXX%cm

C(End yoke Gap): Iron 180cm + α or 280xXX%cm






To accommodate KEK rule, 1mSv/week :


$$1 \text{ [mSv/h]} / 1000 \text{ [mSv/h]} \times 3600 \text{ [s]} = 3.6 \text{ [s]}$$

The system turning off both beam within 3.6 sec must be required

Radiation control area classification of IR hall



Source term of radiation in IR hall



Beam loss points with thick components (Normal, Accidental)

A: Final doublet protection collimator (≈ 0 W, 18 MW)

B: Vacuum valve and flange (≈ 0 W, 18 MW)


C: Beam calorimeter (< 1 W, 18 MW)

D: Luminosity calorimeter (< 1 W, 18 MW)

Pseudo target : Iron 12" L x 2" r (17 X_0 L x 2.8 X_0 r)

Source condition 1; Beam hits beam calorimeter

Beam hits beam calorimeter after passing through final doublet protection collimator




1 m x 15 m


p	Black
n	Green
pi+	Red
pi-	Blue
K+	Grey
K-	Cyan
mu+	Magenta
mu-	Brown
gamma	Light Blue
e-	Orange
e+	Light Green

Points of interest for dose rate evaluation

Plan view



Elevation view





Aspect ratio 1:1 (20 m x 20m)


Result of dose rate evaluation in IR hall

Plan view

Elevation view



Aspect ratio 1:1 (20 m x 20m)



1.39×10^{-2} [mSv/h/kW] (250mSv/h / 18 MW)