



*updated after presentation & discussion*

# Cost Estimating for the AD&I Studies

*proliferation  
of acronyms!*

## Differential Estimates What we need from you!

**Peter H. Garbincius**

**Fermilab**

**DESY – May 29, 2009**



# Introduction & Outline

- Now we need **cost differentials**:  
How much could we save if we made this proposed change?
- Later in the Technical Design Phase – 2:  
we will need a **complete new cost estimate** (bottom-up)
- For Reference Design Report, we had  
estimate =  $a + b + c$     new estimate  $\Rightarrow a' + b + d$   
where  $d$  replaces  $c$ , but may have an **updated estimate** for  $a$   
need to compare  $a+b+c \Rightarrow a+b+d$  or  $a'+b+c \Rightarrow a'+b+d$   
sometimes easy comparing  $b \Rightarrow d$ , sometimes  $b/d$  affects  $a/a'$   
**non-diagonal, coupled effects**
- We need estimate comparison for **same year**  $\Rightarrow$  2007 RDR
- What questions need to be asked for each AD&I study?
- Prior examples: Klystron Cluster & 230 GeV e-e+ studies



# What information we need for each study?

- Descriptive text – what changes
- Configuration – number of new components, # and length of tunnel(s), sketches, 3D CAD, etc.
- Required utilities: power, cooling, cryogenes
- Cost estimates for new components:
  - e.g. overmoded waveguide and couplers for Klystron Cluster study,
  - klystrons and modulators for DRFS
- Do old unit cost estimates change? Learn Curve?
- Use new ICET cost estimate template (enable macros)  
[http://www-ilcdcb.fnal.gov/example\\_26march09-Construction.xls](http://www-ilcdcb.fnal.gov/example_26march09-Construction.xls)
- Head to head comparison: old vs. new (CFS)

**9/4/08**

**RDR**  
**MAR 30 2007**

A5
Main Linac
Denotes changed item
Denotes new item

**ILY Power Cluster Scheme**  
**for Aug 29 2008**

Main Linac
------------

FINAL CONTRACT COST- in 2006 US\$ (except where noted)	
Man-Hours Total	\$ Total
271,161	\$ 1,160,918,228
<b>(still to be corrected RDR)</b>	
	<b>\$ 1,116,055,058</b>

FINAL CONTRACT COST- in 2006 US\$ (except where noted)	
Man-Hours Total	\$ Total
173,933	\$ 821,758,793

1.7	Conventional Facilities	QTY	Unit	Unit Cost	Extension	Section Total
1.7.1	<b>CIVIL ENGINEERING</b>			155,883	Man-Hrs	\$ 737,794,472
1.7.1.1	Engineering, study work and documentation					\$ 38,581,023
1.7.1.1.1	In-house Engineering	\$90	/man-hr	\$14,029,463	155,883	
	In-house Engineering	2%	%	\$701,473,148	\$ 14,029,463	
1.7.1.1.2	Outsourced Consultancy Services					\$ 38,581,023
	Outsourced Engineering	6%	%	\$701,473,148	\$ 38,581,023	
1.7.1.2	Underground Facilities					\$ 593,008,308
1.7.1.2.1	Shafts					\$ 105,194,184
	e- ML 14m dia. Shafts @ Points 5, 3 (2 x 425 vert ft)	259	vert m	\$134,768	\$ 34,904,783	
	e- ML 9m dia. Shaft @ Point 7 (1 x 425 vert ft)	130	vert m	\$78,280	\$ 10,137,260	
	e- ML 1500mm dia. Survey Shafts @ Points 3.1, 5.1 (2 x 425 vert ft)	259	vert m	\$7,240	\$ 1,875,160	
	e- ML 3 m dia shafts @ pts 14,15					
	e+ ML 14m dia. Shafts @ Points 2, 4 (2 x 425 vert ft)	259	vert m	\$134,768	\$ 34,904,783	
	e+ ML 9m dia. Shaft @ Point 6 (1 x 425 vert ft)	130	vert m	\$78,280	\$ 10,137,260	
	e+ ML 1500mm dia. Survey Shafts @ Points 2.1, 4.1 (2 x 425 vert ft)	259	vert m	\$7,240	\$ 1,875,160	
	e+ ML 3 m dia shafts @ pts 16,17					
	Surface Grouting of Points 2-5 14m dia. Shafts (4 x 425 vert ft)	4	ea.	\$721,678	\$ 2,886,710	
	Surface Grouting of Points 6-7 9m dia. Shafts (2 x 425 vert ft)	2	ea.	\$541,258	\$ 1,082,515	
	Surface Grouting of Points 2.1, 3.1, 4.1, 5.1 Survey Shafts (4 x 425 vert ft)	4	ea.	\$270,629	\$ 1,082,515	
	Points 2,3,4,5,6,7 - 14&9m dia. Shafts, finishing (stairs, conc. wall, elev #2)	777	vert m	\$7,254	\$ 5,636,164	
	Surface Grouting of Points 14,15,16,17 Survey Shafts (4 x 425 vert ft)					
	ML Underground Potable Water (1/2 of Points 2 & 3)	1	ea.	\$67,188	\$ 67,188	
	ML Underground Potable Water (Points 4,5,6,7)	4	ea.	\$67,188	\$ 268,750	
	ML Underground Sanitary Sewer (1/2 of Points 2 & 3)	1	ea.	\$67,188	\$ 67,188	
	ML Underground Sanitary Sewer (Points 4,5,6,7)	4	ea.	\$67,188	\$ 268,750	
1.7.1.2.2	Tunnels					\$ 389,191,025
	e- ML 4.5m dia. Beam Tunnel, TBM Excavation (37,162 lin ft)	11,327	lin m	\$7,171	\$ 81,228,749	
	e- ML 4.5m dia. Service Tunnel, TBM Excavation (37,162 lin ft)	11,327	lin m	\$7,171	\$ 81,228,749	
	e- ML 4.5m dia. Tunnels, Conc. Inv. (74,324 lin ft)	22,654	lin m	\$1,351	\$ 30,611,218	
				\$0		
	e+ ML 4.5m dia. Beam Tunnel, TBM Excavation (38,660 lin ft)	11,174	lin m	\$7,171	\$ 80,131,548	
	e+ ML 4.5m dia. Service Tunnel, TBM Excavation (38,660 lin ft)	11,174	lin m	\$7,171	\$ 80,131,548	
	e+ ML 4.5m dia. Tunnels, Conc. Inv. (73,320 lin ft)	22,348	lin m	\$1,351	\$ 30,197,735	
				\$0		
	Provide Tunnel Construction Water Treatment Plant	4	ea.	\$156,250	\$ 625,000	
	Maintain and Operate Tunnel Construction Water Treatment Plant	4	ea.	\$1,160,074	\$ 4,640,295	
	Treatment of Tunnel Construction Water	4	ea.	\$99,046	\$ 396,185	
1.7.1.2.3	Halls					
1.7.1.2.4	Caverns					\$ 66,214,274
	e- ML Shaft Base Caverns D&B Excavation @ Points 3, 5, 7 (3 x 20,056 CY)	46,003	m <sup>3</sup>	\$805	\$ 27,831,815	

QTY	Unit	Unit Cost	Extension	Section Total
		111,674	Man-Hrs	\$ 532,682,498
\$90	/man-hr	\$10,050,613	111,674	\$ 30,151,840
2%	%	\$502,530,659	\$ 10,050,613	
6%	%	\$502,530,659	\$ 30,151,840	\$ 30,151,840
				\$ 393,284,348
				\$ 112,024,494
259	vert m	\$134,768	\$ 34,904,783	
130	vert m	\$78,280	\$ 10,137,260	
259	vert m	\$7,240	\$ 1,875,160	
259	vert m	\$10,635	\$ 2,754,465	
		\$0		
259	vert m	\$134,768	\$ 34,904,783	
130	vert m	\$78,280	\$ 10,176,400	
259	vert m	\$7,240	\$ 1,875,160	
259	vert m	\$10,635	\$ 2,754,465	
		\$0		
4	ea.	\$721,678	\$ 2,886,710	
2	ea.	\$541,258	\$ 1,082,515	
4	ea.	\$270,629	\$ 1,082,515	
777	vert m	\$7,254	\$ 5,636,164	
4	ea.	\$320,560	\$ 1,282,240	
1	ea.	\$67,188	\$ 67,188	
4	ea.	\$67,188	\$ 268,750	
1	ea.	\$67,188	\$ 67,188	
4	ea.	\$67,188	\$ 268,750	
				\$ 165,744,066
11,327	lin m	\$7,171	\$ 81,228,749	
0	lin m	\$0	\$ 0	
11,327	lin m	\$1,351	\$ 15,305,609	
		\$0		
11,174	lin m	\$7,171	\$ 80,131,548	
0	lin m	\$0	\$ 0	
11,174	lin m	\$1,351	\$ 15,098,868	
		\$0		
4	ea.	\$156,250	\$ 625,000	
4	ea.	\$772,009	\$ 3,088,436	
4	ea.	\$66,965	\$ 263,859	
				\$ 18,378,585

**9/4/08**

**RDR**  
**MAR 30 2007**

A5
Main Linac
Denotes changed item
Denotes new item

**KLY Power Cluster Scheme**  
**for Aug 29 2008**

Main Linac
------------

		FINAL CONTRACT COST- in 2006 US\$ (except where noted)	
		Man-Hours Total	\$ Total
	<b>(STILL TO BE CORRECTED IN RDR) e- ML Shaft Base Cavems D&amp;B Excavation @ Points 2, 4, 6 (3 x 20,056 CY)</b>	<b>8,926 m³</b>	<b>\$805 \$ 5,400,230</b>
	e- ML Points 3,5,7 D&B Exc. for Shield Doors (in Base Cavems) (3 x 959 CY)	2,199 m³	\$753 \$ 1,654,522
	e- ML Beam Dump Cavern D&B Excavation @ Point 3 (3,034 CY)	2,320 m³	\$753 \$ 1,745,800
	e+ ML Shaft Base Cavems D&B Excavation @ Points 2, 4, 6 (3 x 20,056 CY)	46,003 m³	\$805 \$ 27,831,815
	<b>(STILL TO BE CORRECTED IN RDR) e+ ML Shaft Base Cavems D&amp;B Excavation @ Points 2, 4, 6 (3 x 20,056 CY)</b>	<b>8,926 m³</b>	<b>\$805 \$ 5,400,230</b>
	e+ ML Points 2,4,6 D&B Exc. for Shield Doors (in Base Cavems) (3 x 959 CY)	2,199 m³	\$753 \$ 1,654,522
	e+ ML Beam Dump Cavern D&B Excavation @ Point 2 (3,034 CY)	2,320 m³	\$753 \$ 1,745,800
			\$0
	Shield Doors @ Base Cavems @ Points 2-7	6 ea.	\$625,000 \$ 3,750,000
			\$ 32,408,826
1.7.1.2.5	Miscellaneous works		
	e- Refuge Areas (14 ea @ 10' x 20' x 10')		
	e+ Refuge Areas		
	e- ML Personnel Crossovers, D&B Excavation (23 X 295.5 CY)	5,196 m³	\$2,158 \$ 11,213,163
	e- ML Waveguides, Drill Excavation (968)	968 ea.	\$5,156 \$ 4,991,250
	e+ ML Personnel Crossovers, D&B Excavation (23 X 295.5 CY)	5,196 m³	\$2,158 \$ 11,213,163
	e+ ML Waveguides, Drill Excavation (968)	968 ea.	\$5,156 \$ 4,991,250
1.7.1.3	Surface Structures		\$ 75,914,855
1.7.1.3.1	Central Lab Buildings		
1.7.1.3.2	Detector Assembly Buildings		
1.7.1.3.3	Office Buildings		\$ 5,057,150
	Points 4-7 Office Buildings (4 x 3,750 sq ft)	1,396 sq m	\$3,623 \$ 5,057,150
1.7.1.3.4	Service Buildings		\$ 17,981,957
	Points 2-7 Electrical Service Buildings (6 x 1,500 sq ft)	836 sq m	\$2,805 \$ 2,344,863
	Points 2-7 Cooling Towers & Pump Stations Bldgs. (6 x 7,500 sq ft)	4,181 sq m	\$2,805 \$ 11,727,120
	Points 2-7 Cooling Ventilation Buildings (6 x 2,500 sq ft)	1,394 sq m	\$2,805 \$ 3,909,975
1.7.1.3.5	Cryo- Equipment Buildings		\$ 24,612,619
	Points 2-7 Cryo - Warm Compressor Building (6 x 4,500 sq ft)	2,508 sq m	\$4,108 \$ 10,301,811
	Points 2-7 Cryo - Surface Cold Box Building (6 x 6,250 sq ft)	3,484 sq m	\$4,108 \$ 14,310,809
1.7.1.3.6	Control Buildings		
1.7.1.3.7	Workshops		\$ 12,822,374
	Points 4-7 Workshop Bldg. - Machine & Detector (4 x 11,250 sq ft)	4,181 sq m	\$3,067 \$ 12,822,374
1.7.1.3.8	Site Access Control Buildings		\$ 782,556
	Points 4-7 Site Access Buildings (4 x 750 sq ft)	279 sq m	\$2,805 \$ 782,556
1.7.1.3.9	Shaft Access Buildings		\$ 14,658,198
	Points 2-7 Shaft Access Buildings (6 x 9,375 sq ft)	5,226 sq m	\$2,805 \$ 14,658,198
1.7.1.3.10	Miscellaneous Buildings		
1.7.1.3.11	User Facilities		
	KLY Cluster Buildings (no of klystron in surface average 60 to 64)		\$38,269,509.84
	Points .16,4,17,6,7,14,5,15,	12,128 sq m	\$2,805 \$34,017,342
	Points 2,3	1,516 sq m	\$2,805 \$4,252,168
1.7.1.4	Site Development		\$ 30,290,286
1.7.1.4.1	Off-site Site work		
1.7.1.4.2	Network of Monuments		
1.7.1.4.3	Construction Support		
1.7.1.4.4	Site Preparation		\$ 1,215,000

		FINAL CONTRACT COST- in 2006 US\$ (except where noted)	
		Man-Hours Total	\$ Total
		6,408 m³	\$805 \$ 3,913,748
		2,199 m³	\$753 \$ 1,654,748
		2,320 m³	\$753 \$ 1,745,800
		6,408 m³	\$805 \$ 3,913,748
		2,199 m³	\$753 \$ 1,654,748
		2,320 m³	\$753 \$ 1,745,800
			\$0
		6 ea.	\$625,000 \$ 3,750,000
			\$ 7,137,201
		1,653 m³	\$2,158 \$ 3,567,869
		1,654 m³	\$2,158 \$ 3,569,332
		0 m³	\$0 \$
		0 ea.	\$0 \$
		0 m³	\$0 \$
		0 ea.	\$0 \$
			\$ 122,001,510
			\$ 5,057,150
		1,396 sq m	\$3,623 \$ 5,057,150
			\$ 25,799,192
		836 sq m	\$2,805 \$ 2,344,863
		6,985 sq m	\$2,805 \$ 19,564,284
		1,394 sq m	\$2,805 \$ 3,909,975
			\$ 24,612,619
		2,508 sq m	\$4,108 \$ 10,301,811
		3,484 sq m	\$4,108 \$ 14,310,809
			\$ 12,822,374
		4,181 sq m	\$3,067 \$ 12,822,374
			\$ 782,556
		279 sq m	\$2,805 \$ 782,556
			\$ 14,658,198
		5,226 sq m	\$2,805 \$ 14,658,198
			\$38,269,509.84
		12,128 sq m	\$2,805 \$34,017,342
		1,516 sq m	\$2,805 \$4,252,168
			\$ 47,244,601
			\$ 2,025,000

**9/4/08**

**RDR**  
**MAR 30 2007**

A5
Main Linac
Denotes changed item
Denotes new item

		FINAL CONTRACT COST- in 2006 US\$ (except where noted)		Man-Hours Total	\$ Total
	Points 2 - 7, Clearing, Grubbing, and Initial Site Preparation (6 sites)	6 ea.	\$202,500	\$ 1,215,000	
1.7.1.4.5	Utility Distribution				\$ 21,046,500
	Points 2 - 7, Utility Corridors (Gas, DWS, San., Storm, Elec., Comm.)	6 ea.	\$3,037,500	\$ 18,225,000	
	Points 2 - 7, Septic Field / Tank or Sanitary Sewer	6 ea.	\$101,250	\$ 607,500	
	Points 2 - 7, Wells or DWS	6 ea.	\$54,000	\$ 324,000	
	Points 4 - 7, Elevated Water Tank	4 ea.	\$270,000	\$ 1,080,000	
	Points 4 - 7, Water Pump House	4 ea.	\$202,500	\$ 810,000	
1.7.1.4.6	Road, Sidewalks & Parking Areas				\$ 7,100,279
	Points 2 - 7, Service Roads (6 sites x 1250 lin ft / site)	2,286 lin m	\$1,107	\$ 2,530,802	
	Points 2 - 7, Paved Areas (6 sites x 8750 sq ft / site)	43,896 sq m	\$97	\$ 4,266,891	
	Points 2 - 7, Flatwork (6 sites x 2,500 sq ft / site)	1,394 sq m	\$217	\$ 302,988	
1.7.1.4.7	Landscaping				\$ 726,007
	Points 2 - 7, Landscaping	6 ea.	\$67,500	\$ 405,000	
	Points 4 - 7, Security Fencing (4 sites x 5,000 lin ft / site)	6,097 lin m	\$53	\$ 321,007	
1.7.1.4.8	Environmental				\$ 202,500
	Points 2 - 7, Sediment & Erosion Control (6 sites)	6 ea.	\$33,750	\$ 202,500	
1.7.1.4.9	Miscellaneous Site Works				
1.7.2	<b>ELECTRICAL</b>		37,585	Man-Hrs	\$ 169,134,000
1.7.3	<b>AIR TREATMENT EQUIPMENT</b>		2,561	Man-Hrs	\$ 12,328,035
1.7.3.1	Engineering, study work and documentation				\$ 806,507
1.7.3.1.1	In-house Engineering	\$90 /man-hr	\$230,431	2,561	
	In-house Engineering	2% %	\$11,521,528	\$ 230,431	
1.7.3.1.2	Outsourced Consultancy Services				\$ 806,507
	Outsourced Engineering	7% %	\$11,521,528	\$ 806,507	
1.7.3.2	HVAC Equipment				\$ 11,521,528
1.7.3.2.1	OA & Exhaust Air Processing				\$ 4,363,546
	OA Supply/Exhaust Systems @ Points 2 - 7	6 ea.	\$727,258	\$ 4,363,546	
1.7.3.2.2	Air-conditioning for Tunnels				\$ 7,157,983
	Beamline Tunnel A/C, e- ML	11,895 lin m	\$90	\$ 1,065,756	
	Beamline Tunnel A/C, e+ ML	10,394 lin m	\$90	\$ 931,267	
	Fan Coil Units	1 is	\$5,160,960	\$ 5,160,960	
1.7.3.2.3	Chilled Water cooling for RF Racks in surface (placeholder)	1 is			\$ 10,000,000
	Air-conditioning for General Areas				
1.7.4	<b>PIPED UTILITIES</b>		266	Man-Hrs	\$ 1,300,792
1.7.4.1	Engineering, study work and documentation				\$ 107,405
1.7.4.1.1	In-house Engineering	\$90 /man-hr	\$23,868	266	
	In-house Engineering	2% %	\$1,193,388	\$ 23,868	
1.7.4.1.2	Outsourced Consultancy Services				\$ 107,405
	Outsourced Engineering	9% %	\$1,193,388	\$ 107,405	
1.7.4.2	Plumbing				\$ 1,193,388
1.7.4.2.1	Potable Water				
1.7.4.2.2	Sanitary Sewer				
1.7.4.2.3	Sump Systems				\$ 1,193,388
	Dewatering Sump Systems at Points 2, 3, 4, 5, 6, 7	6 ea.	\$198,898	\$ 1,193,388	
	Dewatering Sump Systems at Points 14, 15, 16, 17				
1.7.4.3	Fire Suppression				\$ 198,898

**KLY Power Cluster Scheme**  
**for Aug 29 2008**

		FINAL CONTRACT COST- in 2006 US\$ (except where noted)		Man-Hours Total	\$ Total
	Points 2 - 7, Clearing, Grubbing, and Initial Site Preparation (6 sites)	6 ea.	\$202,500	\$ 2,025,000	
1.7.1.4.5	Utility Distribution				\$ 33,817,500
	Points 2 - 7, Utility Corridors (Gas, DWS, San., Storm, Elec., Comm.)	6 ea.	\$3,037,500	\$ 30,375,000	
	Points 2 - 7, Septic Field / Tank or Sanitary Sewer	6 ea.	\$101,250	\$ 1,012,500	
	Points 2 - 7, Wells or DWS	6 ea.	\$54,000	\$ 540,000	
	Points 4 - 7, Elevated Water Tank	4 ea.	\$270,000	\$ 1,080,000	
	Points 4 - 7, Water Pump House	4 ea.	\$202,500	\$ 810,000	
1.7.1.4.6	Road, Sidewalks & Parking Areas				\$ 9,940,391
	Points 2 - 7, Service Roads (6 sites x 1250 lin ft / site)	3,200 lin m	\$1,107	\$ 3,542,843	
	Points 2 - 7, Paved Areas (6 sites x 8750 sq ft / site)	61,454 sq m	\$97	\$ 5,973,388	
	Points 2 - 7, Flatwork (6 sites x 2,500 sq ft / site)	1,952 sq m	\$217	\$ 424,180	
1.7.1.4.7	Landscaping				\$ 1,124,410
	Points 2 - 7, Landscaping	10 ea.	\$67,500	\$ 675,000	
	Points 4 - 7, Security Fencing (4 sites x 5,000 lin ft / site)	6,536 lin m	\$53	\$ 449,410	
1.7.1.4.8	Environmental				\$ 337,500
	Points 2 - 7, Sediment & Erosion Control (6 sites)	10 ea.	\$33,750	\$ 337,500	
1.7.1.4.9	Miscellaneous Site Works				
1.7.2	<b>ELECTRICAL</b>		28,189	Man-Hrs	\$ 126,650,500
1.7.3	<b>AIR TREATMENT EQUIPMENT</b>		4,283	Man-Hrs	\$ 20,818,471
1.7.3.1	Engineering, study work and documentation				\$ 1,348,872
1.7.3.1.1	In-house Engineering	\$90 /man-hr	\$385,392	4,283	
	In-house Engineering	2% %	\$19,269,599	\$ 385,392	
1.7.3.1.2	Outsourced Consultancy Services				\$ 1,348,872
	Outsourced Engineering	7% %	\$19,269,599	\$ 1,348,872	
1.7.3.2	HVAC Equipment				\$ 19,269,599
1.7.3.2.1	OA & Exhaust Air Processing				\$ 7,272,678
	OA Supply/Exhaust Systems @ Points 2 - 7	10 ea.	\$727,268	\$ 7,272,678	
1.7.3.2.2	Air-conditioning for Tunnels				\$ 11,997,023
	Beamline Tunnel A/C, e- ML	11,895 lin m	\$90	\$ 1,065,756	
	Beamline Tunnel A/C, e+ ML	10,394 lin m	\$90	\$ 931,267	
	Fan Coil Units	1 is	\$0	\$ 0	
1.7.3.2.3	Chilled Water cooling for RF Racks in surface (placeholder)	1 is	\$10,000,000	\$ 10,000,000	
	Air-conditioning for General Areas				
1.7.4	<b>PIPED UTILITIES</b>		1,255	Man-Hrs	\$ 6,153,112
1.7.4.1	Engineering, study work and documentation				\$ 508,055
1.7.4.1.1	In-house Engineering	\$90 /man-hr	\$112,901	1,255	
	In-house Engineering	2% %	\$5,645,057	\$ 112,901	
1.7.4.1.2	Outsourced Consultancy Services				\$ 508,055
	Outsourced Engineering	9% %	\$5,645,057	\$ 508,055	
1.7.4.2	Plumbing				\$ 1,988,970
1.7.4.2.1	Potable Water				
1.7.4.2.2	Sanitary Sewer				
1.7.4.2.3	Sump Systems				\$ 1,988,970
	Dewatering Sump Systems at Points 2, 3, 4, 5, 6, 7	6 ea.	\$198,898	\$ 1,193,388	
	Dewatering Sump Systems at Points 14, 15, 16, 17	4	\$198,898	\$ 795,592	
1.7.4.3	Fire Suppression				\$3,658,078

**9/4/08**

**RDR**  
**MAR 30 2007**

A5
Main Linac
Denotes changed item
Denotes new item

**KLY Power Cluster Scheme**  
**for Aug 29 2008**

Main Linac
------------

**FINAL CONTRACT COST- in 2006 US\$**  
(except where noted)

**FINAL CONTRACT COST- in 2006 US\$**  
(except where noted)

		Man-Hours Total		\$ Total	
	e- shafts				
	e-tunnels				
	e-caverns				
	e+ shaft				
	e-tunnels				
	e-caverns				
1.7.4.4	Fuel System Distribution				
<b>1.7.5</b>	<b>PROCESS (COOLING) WATER</b>		<b>38,249</b>	<b>Man-Hrs</b>	<b>\$ 187,809,928</b>
1.7.5.1	Engineering, study work and documentation				\$ 15,490,728
1.7.5.1.1	In-house Engineering	\$90 / man-hr	\$3,442,384	38,249	
	In-house Engineering	2% %	\$172,119,198	\$ 3,442,384	
1.7.5.1.2	Outsourced Consultancy Services				\$ 15,490,728
	Outsourced Engineering	9% %	\$172,119,198	\$ 15,490,728	
1.7.5.2	Primary Stations				\$ 29,863,815
1.7.5.2.1	Cooling Towers & Pumping Stations				\$ 19,875,852
	Cooling Towers for Process Water	1 is	\$9,636,281	\$ 9,636,281	
	Cooling Towers for Chilled Water	1 is	\$5,200,237	\$ 5,200,237	
	Tower Pump and Accessories for Process Water	1 is	\$1,842,963	\$ 1,842,963	
	Tower Pump and Accessories for Chilled Water	1 is	\$1,220,138	\$ 1,220,138	
	Chilled Water Pump	1 is	\$1,191,250	\$ 1,191,250	
	Controls	1 is	\$784,983	\$ 784,983	
	Pump for RF Surface water system (for 10 plants)	1 is			
	Heat Exchanger for RF Surface water system (for 10 plants)	1 is			
1.7.5.2.2	Primary Stations and Piping				\$ 9,987,962
	Chillers	1 is	\$5,347,115	\$ 5,347,115	
	Tower Piping for Process Water (surface)	1 is	\$821,952	\$ 821,952	
	Tower Piping for Chilled Water (surface)	1 is	\$489,039	\$ 489,039	
	Tower Piping for Process Water (shaft)	1 is	\$1,679,547	\$ 1,679,547	
	Chilled Water Piping (surface)	1 is	\$286,335	\$ 286,335	
	Chilled Water Piping (shaft)	1 is	\$1,363,974	\$ 1,363,974	
	Piping RF Surface Water System (for 10 plants)	1 is			
1.7.5.3	Secondary Stations				\$ 142,255,383
1.7.5.3.1	Deminerlized Water Stations and Distribution Piping				\$ 69,245,357
	Deminerlized Pump/Skid System w/ Materials & Installation	1 is	\$69,245,357	\$ 69,245,357	
1.7.5.3.2	Chilled Water Stations and Distribution Piping				\$ 32,456,126
	Heat Exchangers (cavern)	1 is	\$1,726,838	\$ 1,726,838	
	Distribution Pumps (cavern)	1 is	\$1,649,580	\$ 1,649,580	
	Piping (cavern)	1 is	\$399,846	\$ 399,846	
	Piping (tunnel)	1 is	\$19,274,532	\$ 19,274,532	
	Piping Connections to End Equipment	1 is	\$9,405,330	\$ 9,405,330	
1.7.5.3.3	Water Stations and Distribution Piping				\$ 14,473,690
	Water Stations and Distribution Piping	1 is	\$14,473,690	\$ 14,473,690	
1.7.5.3.4	Compressed Air				\$ 2,404,000
	Compressed Air	1 is	\$2,404,000	\$ 2,404,000	
1.7.5.3.5	Process Water Distribution				\$ 23,876,210
	Heat Exchangers (cavern)	1 is	\$2,772,791	\$ 2,772,791	
	Distribution Pumps (cavern)	1 is	\$1,879,121	\$ 1,879,121	
	Piping (cavern)	1 is	\$661,007	\$ 661,007	
	Piping (tunnel)	1 is	\$16,515,925	\$ 16,515,925	

		Man-Hours Total		\$ Total	
648	lin m	\$128	\$82,875		
11,327	lin m	\$128	\$1,448,950		
1	is	\$306,000	\$306,000		
648	lin m	\$128	\$82,875		
11,174	lin m	\$128	\$1,429,378		
1	is	\$306,000	\$306,000		
		<b>17,493</b>	<b>Man-Hrs</b>		<b>\$ 85,507,211</b>
					\$ 7,060,228
		\$90 / man-hr	\$1,568,940	17,433	
		2% %	\$78,448,983	\$ 1,568,940	
		9% %	\$78,448,983	\$ 7,060,228	
					\$ 22,961,993
					\$ 19,234,983
		1 is	\$12,081,000	\$ 12,081,000	
		1 is	\$0	\$0	
		1 is	\$1,639,000	\$ 1,639,000	
		1 is	\$0	\$0	
		1 is	\$0	\$0	
		1 is	\$784,983	\$ 784,983	
		1 is	\$2,416,000	\$ 2,416,000	
		1 is	\$2,314,000	\$ 2,314,000	
					\$ 3,727,000
		1 is	\$0	\$0	
		1 is	\$650,000	\$ 650,000	
		1 is	\$0	\$0	
		1 is	\$651,000	\$ 651,000	
		1 is	\$0	\$0	
		1 is	\$0	\$0	
		1 is	\$2,126,000	\$ 2,126,000	
					\$ 55,485,000
					\$ 34,682,000
		1 is	\$34,682,000	\$ 34,682,000	
					\$ -
		1 is	\$0	\$0	
		1 is	\$0	\$0	
		1 is	\$0	\$0	
		1 is	\$0	\$0	
		1 is	\$0	\$0	
		1 is	\$0	\$0	
		1 is	\$0	\$0	
		1 is	\$0	\$0	
		1 is	\$0	\$0	
		1 is	\$2,404,000	\$ 2,404,000	
					\$ 18,199,000
		1 is	\$1,845,000	\$ 1,845,000	
		1 is	\$1,601,000	\$ 1,601,000	
		1 is	\$316,000	\$ 316,000	
		1 is	\$14,437,000	\$ 14,437,000	

**9/4/08**

**RDR**  
**MAR 30 2007**

A5
Main Linac
Denotes changed item
Denotes new item

**KLY Power Cluster Scheme**  
**for Aug 29 2008**

				FINAL CONTRACT COST- in 2006 US\$ (except where noted)	
				Man-Hours Total	\$ Total
		Piping Connections to End Equipment	1 is	\$1,847,365	\$ 1,847,365
1.7.6		HANDLING EQUIPMENT			\$ 11,300,000
1.7.7		SAFETY EQUIPMENT			\$ 14,020,000
1.7.8		SURVEY AND ALIGNMENT			\$ 27,431,000

				FINAL CONTRACT COST- in 2006 US\$ (except where noted)	
				Man-Hours Total	\$ Total
				\$0	\$ -
				2,511 Man-Hrs	\$ 11,300,000
				2,492 Man-Hrs	\$ 11,218,000
				6,096 Man-Hrs	\$ 27,431,000

**LEGEND (AUG 21 2008)**

- Changes in RDR amount or quantities for the KLY cluster scheme
- New line item added for the KLY cluster scheme

**LEGEND (RDR Dec 2006)**

- Still to be corrected in RDR
- Main CFS WBS level (1.7)
- Second level of WBS (1.7.1 to 1.7.8)
- Third level of WBS
- Fourth level of WBS detail





# CFS criteria for KlyCluster study

Criteria Comparison.xls [Compatibility Mode]

1 Draft - Started Jul 17 2008

2 **DRAFT**  
**Sep 18 2008**

3 Criteria Comparison - Main Linac RF (except where noted with \*)

4

5 **Items shown per RF (except where noted with \*)**

6 units

7 **ILC**

8 POST-RDR (RF on & off) RF Off?? KLY Cluster ILC CFS Workshop Jun 08

9 (from Shigeiki, et. al.) (from Wilhelm) (from Adolphsen) (from Adolphsen)

10 **TESLA** **XFEL** **CLIC** **Proj X**

11 RF On RF Off RF On RF Off

12 \*Tunnel Scheme

13 deep two-tunnel single tunnel ?? near surface single-tunnel near surface single-tunnel ??? near surface single-

20

21 **Process Water Circuit (RF watercooled components)**

22 Collector Heat Load to water KW 45.8 Shigeiki/Adolphsen et. al. 30? (wilhelm) 60 45.8 31.9 91.13 282

23 Location service tunnel surface surface tunnel tunnel

24 Collector Water Flow given l/min not given 37 37 37 35 282

25 gpm not given 9.77 9.8 9.8 9.25 74

26 Collector Water Delta T C not used 18 23 18 14

27 F not used 32 42 32 26

28 Maximum allowable Temperature C not given 87 87 87

29 F not given 189 189 189

30 Maximum allowable pressure Bar not given 15 15 15

31 Psi not given 59 59 59

32 Pressure drop Bar 2 0.3 0.3 0.3

33 Psi 29 32 32 32

34 Supply Temperature Stability not given none

35 Circulator Heat Load to water (for 26 qty) KW not given 2.49

36 Circulator quantity per RF 26 36 32

37 Circulator Water Flow l/min not given 26.78 28.8

38 gpm not given 7.1 7.6

39 Maximum allowable Temperature C not given

40 F not given

41 Maximum allowable pressure Bar not given

42 Psi not given

43 Pressure drop Bar not given

44 Psi not given

45 Supply Temperature Stability +- 2.5 C

46 RF Load Heat Load to water KW none 30.05



# KlyCluster est did not use Chilled Water!

Criteria Comparison.xls [Compatibility Mode]																	
	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
1																	
2	Draft - Started Jul 17 2008	<b>DRAFT</b> <b>SEP 18 2008</b>		blue shade indicate numbers that are <u>arbitrarily</u> adjusted to increase water delta T in post RDR													
3	Criteria Comparison - <u>Main Linac RF (except where noted with *)</u>	notable differences ??															
4																	
5	<b>Items shown per RF (except where noted with *)</b>	<b>units</b>		<b>ILC</b>				<b>TESLA</b>		<b>XFEL</b>		<b>CLIC</b>	<b>Proj X</b>				
6				POST-RDR (RF on & off)	RF Off??	KLY Cluster	ILC CFS Workshop Jun 08	RF On	RF Off	RF On	RF Off						
7				( from Shigeki, et. al.)	( from Wilhelm)	( frm Adolphsen)	( frm Adolphsen)										
8	*Tunnel Scheme			deep two-tunnel			single tunnel	??	near surface single-tunnel		near surface single-tunnel		???	near surface single-			
166	<b>Chilled Water Circuit (Watercooled Racks and other heat load to air)</b>																
167	Tunnel Space Temperature	C	29	> 40			> 40	Negligible 'Heat load to air' in the tunnel in this scheme??									
168		F	85	> 104 ?			> 104 ?										
169	Tunnel temperature Stability	%	none	none			none										
170	Tunnel Space Humidity	%RH	non-condensing	none			none										
171	Heat Load to Air (waveguide) beam tunnel	KW	none given	5.9			5.9										
172	Heat Load to Air (RF component) svc trnl	KW	10.1	Ignored. (very warm tunnel space)??			Ignored. (very warm tunnel space)	assumed none (??) absorbed in tunnel wall		assumed none (??) absorbed in tunnel wall							
173	Heat Load to Air (non-rf component)	KW	16														
174	Heat Load to Air in w/m	w/m	687														
175	RACKS Total Heat Load per RF	KW	11.5	5.75			Only 1 KW remain in tunnel. (10 kw remain in surface										
176	RACKS Minimum supply temperature	C	non-condensing	reduced to 50%						18							
177		F	non-condensing							64.4							
178	*Conceptual Design Scheme		watercooled racks supplied with blended cold water (from chilled water)	self contained racks with chiller supplied with process water (rack w chiller cost not by cfs)				only 1kw rack in tunnel(ignored). The other cluster in surface used underfloor data center aircooling					existing cold water, available at the center point of the accelerator				
179	*Total load to Chilled Water (RF+Rack+non-RF)	KW	37.6				none	0									
180	*Supply Temperature used in chilled water	C	6								6						
181		F	43								43						
182	*Delta T used in chilled water	C	10								12						
183		F	18								21.6		10.8				
184	*Total Load for a representative water plant	MW	3.9				Chilled Water distribution- not used.										
185	*Total Flow per representative plant	l/min	5614														
186		gpm	1483														
187	*Main Pipe Size in representative plant	mm	250														
188		in	10														
189																	



# Comparison of klyCluster vs. RDR Estimates

## SENSITIVE COST ESTIMATE INFORMATION

Peter H. Garbincius and Tom Lackowski

August 22 2008 revised September 4, 2008

for incorrect +/- sign – changes highlighted in yellow

filename: klyCluster\_estimate\_4sept08.doc

note: Adjusted RDR Estimate => The total CFS base number has been corrected to reflect the actual costs of the shaft base cavern spaces that were based on overestimated, incorrect cavern volumes ( $6 * 15,334 \text{ m}^3 = 92,0006 \text{ m}^3$ ) in the RDR estimate. The Americas' ML RDR estimate (\$ 1,160.9 M) was first adjusted to more correct ( $6 * 2,795 \text{ m}^3 = 17,852 \text{ m}^3$ ) shaft base cavern volumes (=> \$ 1,116.1 M), to which the estimates for the alternative klystron placement was compared. This was done so that the savings reflected for the new klystron scheme were not artificially inflated.

**This is for Main Linac only for 560 RF units**

	<u>adjusted</u> <u>estimate</u>	klyCluster <u>estimate</u>	2007 \$ <u>difference</u>
<u>Americas' only</u> CFS Estimate (2006 unit costs)			(negative => savings)
reference spreadsheets: 30march07, 29aug08	\$ 1,116.1 M	\$ 821.8 M	-\$ 294.3 M
escalate difference 2006 => 2007 @ 1.106			-\$ 325.5 M
CF&S institutional labor	271 K man-hrs	195 K man-hrs	-76 K man-hrs

Remove ~ 2\*11 meters of WR 650 wg per RF unit

between klystron and cryomodules through penetration  
and across beam and service tunnels

at \$ 249 per meter (2006) = \$ 5.48 K/RF unit \* 560 RF units

= \$ 3.1 M escalate difference 2006 => 2007 @ 1.0323

-\$ 3.2 M

I assume all other RF hardware, plumbing, & accessories are needed

HLRF WBS SUM 121906 rsl-mn.xls

PHG: I don't understand Ray Larsen's spreadsheet line 44 so just use his base quote of \$ 249/meter



Add  $\approx 1,370$  meters of RF pipe per 30 RF units  
at \$ 1 K per meter \* 560 RF units +\$ 25.6 M  
estimate from Chris Adolphsen (28july08)

Add \$ 20 K per RF unit for coaxial RF couplers \* 560 RF units +\$ 11.2 M  
estimate from Chris Adolphsen (28july08)

Add extra control and LLRF cables, alcoves, RTML services in ML tunnel,  
radiation shielding of tunnel electronics, & needed other stuff not estimated

total change in 2007 \$ (negative => savings) +\$ 33.6 M - \$ 325.5 M = -\$ 291.9 M

**Note:** This difference estimate is only for Main Linac (560 RF units). There are another similar 32 RF units and service tunnel for RTML. This covers 2\*BC2(15 RF units each) + 2\*BC1(only take 1 RF unit each since the 100% backup can be provided by the other high power RF drivers on the same RF pipe). So, as a first order, average estimate of the savings for the combined Main Linac + RTML-BC1 + RTML-BC2 would be to multiply by  $(560+32)/560 = 1.057$ . Notice that this coupling of RF drivers could also remove two RF driver systems for the backups for RTML BC1's which is approximately \$ 1.164 M (2006) \* 1.0323 = \$ 1.2 M (2007) each. This could be partially offset by needs of 2 additional RTML shafts for these Rfpipes. Similar savings by removing second tunnel for Electron Source, Positron Source, and Beam Delivery Systems have **NOT** been considered yet.

*Peter*



PLC\_studies\_PHG\_feb09.xls  
tab: 230 e+e-

## 230 GeV e+e- study was a 36-step process

Michael Peskin wants to know how this cost scales with energy around 230 GeV, e.g. 200, 230, 260 GeV

This uses a conventional positron source, see Kuriki notes, instead of undulator

The 100 GeV Main Linacs are such that the end of the RTML is still within the position of undulator source so no interference for upgrade later

This method (see tab: Geometry) can go up to 259 GeV e+e- without interfering with undulator positron source

So what needs to be done:

### Electron Source:

done nothing to do, remains as is

### Positron Source:

done remove undulator insert cost, both civil and technical

done removed Keep Alive Positron source, but re-used target, dump, collection stages from undulator source

done keep positron source tunnel

done add a conventional positron source in positron source tunnel (dual gun)

done 2.2 GeV electron source (assume you can get required 4.5 nC charge per bunch for same cost)

use same estimate forced flow liquid lead production target - Sheppard had 3.9 M ILC in RDR, Kuriki-san says a few \* \$ 100 K

done beam dump for XXX MW don't use 19 MW upgrade dumps => could use 5 MW dumps scaling by energy

done then add same positron source OMD, acceleration, transport

did not add Kuriki-san's Lithium Lens

### Damping Rings: remain Identical from RDR design

done remain Identical to RDR design

### RTML:

done keep 90-degree bends from DR, and 180-degree turn-arounds identical

scale length and cost of long transport from 90-degree bend to 180-degree turn-arounds by length of main linac

of course, problem is figuring out how much of this is what....

done scaled length of long transport vacuum by 0.417 (see page 5)

done removed 233 RETURNCELLEs = 4 quads, 3 trims, 2 BPMs each (see page 5)

done scaled cost of power supplies by new cost of RTML magnets = 0.855 (see page 5-6)



Main Linac:

done reduce/scale energy/length by  $2*(250-15)=2*235=470$  to  $2*(115-15)=2*100=200 = 0.425532$   
 done remember to reduce length of service tunnel = shared with e- and e+ service tunnels (previously shared with BDS)

done How many RF units and magnets are needed w 560 238.2979 round to 240 120 per side  
 done How many cryo plants ? Was (per side) 5 2.12766 This is more than 2, we could have 3 smaller plants per side or  
 scale by total energy for RTML + ML two bigger plants per side - what is cost scaling?

done How many shafts needed? assume 2 each per side 14 m dia - same for base cavern  
 done Surface structures and site development - scale by number of sites => 6 => 4

done Learning Curve, 86% Wright => comparing 613 with  $613-560+240=293$  => extra cost for <RF and CM> is 1.173  
 this applies to ALL CM and RF units: e-, e+, RTML, and ML I'll call this "Learning Curve extra cost"

BDS:

done reduce length from 2620 meters each side to 800 meters each side 0.305344 remember full length service tunnel  
 reduce technical components & "utilities" 500 GeV to 230 GeV each side 0.46

Also:

reduce all utilities and common technical stuff

	technical	"utilities"
e-	n.a.	n.a.
e+	done	done
DR	n.a.	n.a.
RTML	done varies	ignore
ML	done 0.425	done 0.425
BDS	done 0.46	done 0.46
Exp Hall	n.a.	n.a.
Common	n.a.	done 0.640

see 8feb09 - page 7

also scaled # sites by 4/6

this is scaling common central transformers for new total power at reduced energy

done see page 9: for outsourced engineering on surface structures + site development,  
 I used (average outsourced engineering rate) \* (case multiplier) \* (average surface + site)  
 where "average" = (European+Asian+Americas)/3  
 this really should have been  
 (European eng rate) \* factor \* (Euro surface+site)  
 plus (Asian eng rate) \* factor \* (Asian surface+site)  
 plus (Americia eng rate) \* factor \* (America surface+site)  
 last step 36 => see pages 13-14



## Questions & Comments on Nick's List

- **e- Source:** easy! where? service tunnel/caverns?
- **e+ Source:** keep undulator source, not conv e+  
what is QWT?, what about Lithium lens? What is aux. e- linac for e+ production? Warm or cold?  
Where is it located wrt ML/BDS, undulator, RTML?
- **DR:** RDR had 6.7 km OSC6 - Susanna (today) has a 3.3 km DCO racetrack with straights = 2\*1 km and  $R_{\text{arcs}} = 200 \text{ m} \Rightarrow$  close to TBM turning limit  
need new estimate using new component #s
- **RTML:** remember impact of 210 m shorter single BC on long transfer lines – Nikolay has new # of similar comps – same (or scaled) RDR unit costs



## Nick's List - continued

- **Main Linac:** need better estimates for 300 MW RF pipe & couplers, DRFS klystrons & modulators, space considerations for 1-tunnel and shafts
- **BDS:** what configurations will we estimate?  
500 GeV easily upgradable to 1 TeV  
Checks of design & simulation for traveling focus.
- **Low-P:** specify all configurations:  
half-number of klystrons, full number of klystrons,  
upgradability: during operations? 1 or 2 tunnels,  
with or without Klystron Cluster (easy on surface)  
Is immediate upgrade considered a cost saving?





## *Peter's simple ?s on central region*

- impacts to RDR geometry
  - Length of new BDS? (~ same as old =  $\pm 2226$  m), where e- source, e+ source, RTML lines join? **Ewan: anywhere**
  - Longer RTML lines, different e+ 5 GeV injection line to DR
  - Flexibility in locating e- Source => facilitate commissioning
  - Any ML needed d.s. of undulator?  **$\epsilon$ -growth acceptable**
  - Transverse offset of DR straights from ML/BDS line?
  - Will have enough  $n \cdot 7^\circ$  dipole bends for Spin Rotation
  - Crowding: ML 250 GeV e- bypass, aux. e- drive for e+,  $\gamma$ -beam from undulator, e- RTML, target station with shielding (**how much?**), and don't forget serviceability
  - Do any of these systems require service tunnels or special service caverns?



## *Peter's Final Comments/Questions*

- We've started to see updates to the risk register!
- How do we weigh a cost estimate impact versus machine availability?
- Yes, we all agree that we must work together to produce this new Strawman Baseline!  
Is there enough personnel resources to do it?
- Ewan asked for answers on Central Region Integration Case 3 by this afternoon ~ like now!
- Do we know what we need to do in order to have differential cost impacts for Albuquerque?

ICET cost estimate template (enable macros):

[http://www-ilcdcb.fnal.gov/example\\_26march09-Construction.xls](http://www-ilcdcb.fnal.gov/example_26march09-Construction.xls)



## *discussion during & after presentation:*

- Barry: how do we deal with currency exchange rate changes? Past and Future? PPP index? How complicated do we need to be?
- Nick: preparing for Albuquerque meeting: need deadline for submission of pre-information likely prioritization of studies (limited resources)
- Peter: need to better specify information needed from TAGLs and estimators  
Nick: show estimate info in ICET template  
require only simple TAGL input  
to be logged by ICET experts