



Argonne HPR system Contamination

Problem

- Upon removal of the filter that is at the bottom of the spray nozzle for the Argonne HPR System a *Brown Contaminant* was found
- Additional filter was added after high pressure manifold. New manifolds were manufactured and installed.
- After running of 1500 gallons of DI water through the additional filter in Argonne HPR system with Pump On filter color changed. Filter that is at the bottom of the spray nozzle stays white.





UNLESS OTHERWISE SPECIFIED			ORIGINATOR	D.O.LIS	10-JUL-2008
±	±	±	DRAWN	T.HAMERLA	12-MAR-2009
			CHECKED	D.O.LIS	12-MAR-2009
			APPROVED	A. ROWE	13-MAR-2009

1. BREAK ALL SHARP EDGES MAX	USED ON
2. DO NOT SCALE DRAWING.	
3. DIMENSIONS BASED UPON ASME Y14.5M-1994	
4. MAX. ALL MACH. SURFACES	
5. DRAWING UNITS: U.S. INCH 32	MATERIAL ULTRA PURE FITTING WITH BCF CONNECTIONS & STAINLESS STEEL

FERMI NATIONAL ACCELERATOR LABORATORY
UNITED STATES DEPARTMENT OF ENERGY

**SCRF - HIGH PRESSURE RINSE
HPR STATION
PID ANL RM B-101, BLDG 208**

SCALE	DRAWING NUMBER	SHEET	REV
NONE	5525.000-MC-457283	1 OF 1	

CREATED WITH: IDeas12NXSeries GROUP: ACCELERATOR MECH. SUPPT.

NOTICE: IMAGE OBTAINED FROM FERMILAB WEB SITE
This information is provided for REFERENCE use only.
Not for MANUFACTURE, or DESIGN INFORMATION.
All information contained in this document represents
work sponsored by an agency of the U.S. Government.
Neither the U.S. Government nor any agency thereof,
nor Universities Research Association, Inc., nor any of
their employees or officers, makes any warranty, express
or implied, or assumes any legal liability or
responsibility for the accuracy, completeness, or
suitability of any information, apparatus, product or
process disclosed, or represents that its use would not
infringe privately owned rights.




HPR system in Argonne




HPR system in IB4


New versions of manifolds were made in September 2009 by Holland Applied Technologies.



- NOTES:
- 1) FABRICATE PER ASME B31.3, NORMAL SERVICE, 2000PSI OPERATING PRESSURE, 100° F. OPERATING TEMPERATURE. VENDOR'S CERTIFICATION OF CODE COMPLIANCE TO BE DELIVERED WITH ORDER.
 - 2) WELDING PROCEDURE SPECIFICATIONS (WPS) AND WELDER PERFORMANCE QUALIFICATIONS TO BE SUPPLIED TO FERMILAB PRIOR TO FABRICATION.
 - 3) MATERIAL CERTIFICATIONS ARE REQUIRED AND MUST BE INCLUDED WITH ORDER.
 - 4) INTERNAL ZONE OF EACH WELD MUST BE MECHANICALLY POLISHED TO 20 μ -in Ra INDIVIDUALLY. INSPECTION REPORT IS REQUIRED. ▲
 - 5) FINALLY ELECTROPOLISH INTERIOR PASSAGES TO 4 μ -in Ra AVERAGE. ▲
 - 6) PIPE SEGMENTS ARE TO BE CUT TO ACHIEVE NOTED ASSEMBLY FLANGE CENTER DISTANCES.

10
9
8
7
6
5
4
3
2
1
A
B
C
D
E
F
G
H



5525.000-ME-457423 MANIFOLD-HIGH PRESSURE LEWA PUMP			 APPLIED TECHNOLOGIES	7050 HIG BURR RIDGE (830) 325-5130 PH. (6) www
W.D. # 32739	QUANTITY: 1	DATE: 09-04-09		DESIGNED BY: CVASSOS
MATL: T316L	INTERIOR FINISH: 20 RA & ELECTROPOLISH ORB. WELDS AS-IS	EXTERIOR FINISH: 32 Ra (150 GRIT) REMOVE WELD DISCOLOR.	DRAWN BY: CVASSOS	SCALE: NTS
UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS GIVEN IN INCHES RECORD ALL 316/316L HEAT NUMBERS			DATE DRAWN: 8/17/2009	
.XXX ±.005	.XX ±.060	.X ±.125	APPROVED BY:	

Supplier manufacturing drawing

CUSTOMER DATA					HAT DATA				Q/A SIGNATURES		
CLIENT		FERMI LAB			DATE	8/19/2009		Dan Kosmos			
PROJECT		MANIFOLD-HIGH PRESS. LEWA			JOB ORDER	32739					
PROJECT NUMBER					DRAWING	9285-001		WELDER SIGNATURES			
PO NUMBER					SHEET NUMBER	0		Thomas C. Hughes / Thomas C. Hughes			
GAS LOT NO / CERT ID/OD		080309-1379			REVISION	A.1					
GAS LOT NO / CERT ID/OD					SHEET 1 OF 2						
FILLER WIRE HEAT NUMBER		520432									
LOG NO.	DATE	WELD PROCEDURE	MACHINE ID #	WELD ID #	HEAT NUMBER 1	HEAT NUMBER 2	SIZE	WELDER INITIALS	QUALITY CONTROL		
									ACCEPTED	REJECTED	NOTES
1	11SEP09	HAT-A-01	HAT02	23	70041	825161	1.00	TCU	OK		
2	11SEP09	HAT-A-01	HAT02	24	824090-100	825161	1.00	TCU	OK		
3	11SEP09	HAT-A-01	HAT02	25	70041	825161	1.00	TCU	OK		
4	11SEP09	HAT-A-01	HAT02	26	70041	825161	1.00	TCU	OK		
5	11SEP09	HAT-A-01	HAT02	3	816515-100	825161	1.00	TCU	OK		
6	11SEP09	HAT-A-01	HAT02	4	825161	822778	1.00	TCU	OK		
7	11SEP09	HAT-A-01	HAT02	7	822778	825161	1.00	TCU	OK		
8	11SEP09	HAT-A-01	HAT02	8	825161	824090-100	1.00	TCU	OK		
9	11SEP09	HAT-A-01	HAT02	11	824090-100	825161	1.00	TCU	OK		
10	11SEP09	HAT-A-01	HAT02	12	825161	822778	1.00	TCU	OK		
11	11SEP09	HAT-A-01	HAT02	15	822778	825161	1.00	TCU	OK		
12	11SEP09	HAT-A-01	HAT02	16	825161	822778	1.00	TCU	OK		
13	11SEP09	HAT-A-01	HAT02	19	822778	825161	1.00	TCU	OK		
14	11SEP09	HAT-A-01	HAT02	20	825161	816613-100	1.00	TCU	OK		

1ST WELD ID NUMBERS PER THE DRAWING. REWELDS, WHERE ALLOWED, ARE LISTED AS THE ORIGINAL NUMBER FOLLOWED BY AN "R," FOR EXAMPLE, "2R." ONLY ONE REWELD IS ALLOWED PER ASME BPE 2002. REPLACEMENT WELDS WILL BE MARKED WITH WELD NUMBER PLUS LETTER. FOR EXAMPLE: "1A" IS THE REPLACEMENT WELD FOR "1." "1B" IS THE REPLACEMENT WELD FOR "1A".

Weld log with
inspection report

(05) **Table MJ-3 Acceptance Criteria for Welds on Tube**

Discontinuities	Product Contact Surfaces	Nonproduct Contact Surfaces
Misalignment (mismatch) [see Note (1)]	Maximum of 15% of nominal wall thickness [see Fig. MJ-1(b)], except that 4 in. tube may have a maximum of 0.015 in. (0.38 mm) misalignment on the OD and 6 in. tube may have a maximum of 0.030 in. (0.76 mm) misalignment on the OD. Figure MJ-1(b) does not apply to 4 in. and 6 in. tube.	Same as product contact surfaces
Concavity [see Note (1)]	Maximum of 10% of the nominal wall thickness [see Figs. MJ-1(c) and MJ-1(d)]. However, OD and ID concavity shall be such that the wall thickness is not reduced below the minimum thickness required in DT-5.	Maximum of 10% of the nominal wall thickness [see Figs. MJ-1(c) and MJ-1(d)] over entire circumference with up to 15% of the nominal wall thickness permitted over a maximum of 25% of the circumference.
Convexity [see Note (1)]	Maximum of 10% of the nominal wall thickness [see Fig. MJ-1(f)]	Maximum of 0.015 in. (0.38 mm) [see Fig. MJ-1(f)]
Cracks	None allowed	None allowed
Lack of fusion	None allowed	None allowed
Undercut	None allowed	See Note (2)
Arc strikes	None allowed	See Note (3)
Incomplete penetration	None [see Fig. MJ-1(e)]	None [see Fig. MJ-1(e)]
Tack welds	Must be fully consumed by final weld bead [see Note (4)]	Same as product contact side [see Note (4)]
Discoloration (weld bead)	None allowed	Discoloration level will be agreed upon between the owner/user and contractor. AWS D18.2 may be used as a reference for this purpose. Postweld conditioning may be allowed to meet discoloration requirements at the discretion of the owner/user.
Discoloration (heat-affected zone)	Heat-affected zone (HAZ) may be permitted to have light straw to light blue color (for example, AWS D18.2 samples 1 through 3 may be used as a guide). Any discoloration present must be tightly adhering to the surface such that normal operations will not remove it. In any case, the HAZ shall have no evidence of rust, free iron, or sugaring. See Note (5).	Discoloration level will be agreed upon between the owner/user and contractor. AWS D18.2 may be used as a reference for this purpose. Postweld conditioning may be allowed to meet discoloration requirements at the discretion of the owner/user. See Note (5).
Tungsten Inclusions	None open to the surface; otherwise, see Note (2).	See Note (2)
Weld bead width	No limit provided that complete joint penetration is achieved on groove welds.	If product contact surface cannot be inspected (such as ID of a tube beyond the reach of remote vision equipment), then the non-product contact surface weld bead shall be straight and uniform around the entire weld circumference [see Fig. MJ-1(g)]. The minimum weld bead width shall not be less than 50% of the maximum weld bead width [see Fig. MJ-1(h)]. The maximum weld bead meander shall be 25% of the weld bead width, measured as a deviation from the weld centerline, as defined in Fig. MJ-1(i).
Porosity	None open to the surface; otherwise, see Note (2).	None open to the surface; otherwise, see Note (2).

GENERAL NOTE: All repairs shall comply with ASME B31.3.

NOTES:

- (1) In the case of two different wall thicknesses, any acceptance criteria listed in terms of nominal wall thickness shall be based on the nominal wall thickness of the thinner tube.
- (2) The limits of ASME B31.3, paras. 341.3.2 through 341.3.4 and Table 341.3.2, along with the criterion value notes for Table 341.3.2, will apply.
- (3) Arc strikes on the non-product contact surface may be removed by mechanical polishing as long as the minimum design wall thickness is not compromised.
- (4) Any welds which show unconsumed tack welds on the non-product contact surface must be inspected on the product contact surface; otherwise they are rejected. If the weld cannot be inspected on the product contact surface, rewelding per para. MJ-6.4.1 is not allowed. Rewelding per para. MJ-6.4.1 is allowed if the weld can be inspected on the product contact surface after rewelding.
- (5) Welds on tubing that has been in service may require unique criteria.






Fig. MJ-1 Acceptable and Unacceptable Weld Profiles for Tube Welds



Weld acceptance / rejection criteria

ASME BPE-2005, Bioprocessing equipment



MTR REPORT DATE PRINTED : 09/23/09

The material producer has certified that this material has been manufactured, sampled, tested, and inspected in accordance with the specification, including year date and supplementary requirements, and that the results meet the requirements of this specification.
MATERIAL IS FREE OF MERCURY CONTAMINATION!

Signature on file
 Paul F. Nehlen
 General Manager

Sold To :
 FERMI LAB

Ship To :

5525.000-ME-457423 HAT JOB 32739

Sales Order No.: 328211

Customer Part No.:

Customer PO No.: 587683

Quantity:

Heat I.D.
 824090-100

LIMITS

CHEMICAL REQUIREMENTS																
C	Mn	P	S	Si	Cr	Ni	Mo	Cu	Co	N	Cb	Ti	Fe	Sn	Bi	Fer
0.015	1.420	0.028	0.013	0.420	16.300	10.100	2.110	0.330	0.560	0.040						4.120

Actuals
 1.0 INCH 316L / ASTM A-269/270/ASME SA-249

LIMITS

MECHANICAL REQUIREMENTS					
Tensile Min (psi)	Yield Min (psi)	Elongation Min %	Hardness Max	Red. Area Min %	Grain Size
89000	58200	58.000	RB 85		

Actuals



September 22, 2009

Holland Applied Technologies
7050 High Grove Blvd
Burr Ridge, IL 60527

This is to certify that the following parts were processed according to standard process and your purchase order specifications:

PART NO.	Various
PART DESCRIPTION	SUB-5525.000-ME-457423
PURCHASE ORDER NO.	S03892
QUANTITY SHIPPED	1 PCS.
OPERATION PERFORMED	Passivate
PACKING LIST NO.	361434-00
LOT NUMBER	
SPEC NUMBER	
REMARKS	JOB #32739

CERT DESCRIPTION Passivate Per ASTM A967-05e1

ABLE ELECTROPOLISHING COMPANY

John S. Glass
President

Marcia



Phone: 1.888.868.2900 • Fax: 773.277.1655 • www.ableelectropolishing.com
CHICAGO Corporate Headquarters Production Facility: 2001 S. Kilbourn Ave. • Chicago, IL 60623



Manifolds were electropolished and passivated by ABLE Electropolishing

CERTIFICATE OF CONFORMANCE

CUSTOMER: **LEWA, INC.**

CUSTOMER P.O. #: 19380

PART OR DWG. # LDE2/M9/46 PUMP

4 VALVE BODIES / 2 DIAPHRM BODIES / 4 VALVE SEATS /
4 VALVE GUIDES / 4 VALVE PLATES / 4 SPRINGS

AL-REF#: FERMILAB 22620

SURFACE TREATMENT ID: MECHANICAL POLISH, EP & ULTRASONIC PASSIVATE

SURFACE TREATMENT OD: MECHANICAL POLISH, EP & ULTRASONIC PASSIVATE

ID SURFACE FINISH IS LESS THAN OR EQUAL TO: 20 RA

MATERIAL USED: CUSTOMER SUPPLIED

OLYMPIC SYSTEMS CORPORATION HEREBY CERTIFIES THAT ABOVE SURFACE TREATMENT PROCESS AND SURFACE FINISHES CONFORM TO CUSTOMER REQUIREMENTS.

DATE: 1/29/10

QUALITY CONTROL INSPECTOR: 

OLYMPIC SYSTEMS CORPORATION, 15 LOWELL AVENUE, WINCHESTER, MA. 01890
781-721-2740 FAX: 781-729-4831

LEWA
pumps + systems

**WERKSZEUGNIS
TEST REPORT
RELEVÉ DE CONTRÔLE
EN 10204 - 2.2**

Besteller/Purchaser/Commandant: LEWA, Inc.	Bestell-Nr./Order no./Numéro de commande: PO 18889 / SO 22620 Fermilab PO 588993	Positions-Nr./Item no.:
LEWA-Auftrags-Nr./Commission no./Référence: E12-522790	Erzeugnis / Product / Produit: Metering pump	Typ / Type / Type: LDE2 M911S Gr. 46

Für die fluidberührten Teile wurden nachstehend spezifizierte Werkstoffe verwendet:

For the wetted parts the materials specified below have been used:

Les matériaux définis ci-dessous ont été utilisés pour les pièces en contact avec le fluide:

Teil / part / Pièce	Element / element / Élément	Werkstoffe / materials / matériaux				
		a	b	c	d	e
Pumpenkörper / pump body / Corps de pompe		-	-	-	-	-
Membranpumpenkörper / diaphragm body / Corps de pompe à diaphrag.		1.4571	1.4571			
Tauchkolben / plunger / Piston plongeur		-	-	-	-	-
Membrane / diaphragm / Diaphragme		PTFE	PTFE			
Faltenbalg / bellows / Soufflet		-	-	-	-	-
Ventilsitz / valve seat / Siège de soupape		1.4571	1.4571			
Ventilführung / valve guide / Guide de soupape		1.4571	1.4571			
Ventilkugel / Kegel / Platte / valve ball / cone / plate / Bille / Cône / Disque		1.4571	1.4571			
Ventilfeder / valve spring / Ressort de soupape		1.4571-FH	1.4571-FH			
Ventilkörper / valve body / Corps de soupape		1.4571	1.4571			
Flansch / flange / Bride		-	-	-	-	-

Werkstoff-Nr.: material no.:	Bezeichnung designation Designation	Analyse [%] / analysis [%] / Composition du matériau [%]							Rm [N/mm ²]	Rp0,2% [N/mm ²]	Härte hardness Dureté
		C	Si	Mn	Cr	Mo	Ni	Sonstiges Autres			
1.3541 H	X 45 Cr 13	0,42-0,50	≤1	≤1	12,5-14,5	---	≤1	P<0,040 S<0,03	---	---	57-62 HRC
1.4122	X 35 CrMo 17	0,33-0,43	≤1	≤1	15,5-17,5	0,9-1,3	(≤1)	P<0,045 S<0,03	---	600	235-285 HB
1.4301	X 5 CrNi 18 10	≤0,07	≤1	≤2	17-19	---	8,5-10,5	P<0,045 S<0,03	500-700	195	130-180 HB
1.4401 (K)	X 5 CrNiMo 17 12 2	≤0,07	≤1	≤2	16,5-18,5	2,0-2,5	10-13	P<0,045 S<0,03	500-700	205	130-180 HB
1.4435	X 2 CrNiMo18-14-3	≤0,03	≤1	≤2	17-19	2,5-3	12,5-15	P<0,045 N<0,11	500-700	200	≤ 215HB
1.4528	X 105 CrCoMo 18 2	1,00-1,10	≤1	≤1	16,5-18,5	1,0-1,6	---	Co 1,3-1,8	≤900	---	---
1.4539	X 1NiCrMoCu 25-20-5	≤ 0,02	0,7	≤2	19-21	4-5	24-26	P<0,03 S<0,01	530-730	230	≤ 230HB
1.4571 (FH)	X 6 CrNiMoTi 17 12 2	≤0,08	≤1	≤2	16,5-18,5	2,0-2,5	10,5-13,5	Ti>5%<C	500-750	225	130-190 HB
1.4581	G X5 CrNiMoNb 19-11-2	≤0,07	≤1,5	≤1,5	18,0-20,0	2,0-2,5	9,0-12,0	Nb>8%<C	440-650	165	130-200 HB
2.4602 (FH)	NiCr21Mo 14 W	≤0,01	≤0,08	≤0,5	20-22,5	12,5-14,5	Rest:Bal.	Co/Fe/W	690-950	310	≤ 205 HB
2.4610	NiMo 16 Cr 18 Ti	≤0,015	≤0,08	≤1	14,0-18,0	14-17	Rest:Bal.	Ti 0,5-0,7	700-900	230-305	≤ 240 HB
2.4819	NiMo 16 Cr 15 W	≤0,01	≤0,08	≤1	14,5-16,5	15-17	Rest:Bal.	Co / Fe / W	700-950	280	≤ 240 HB
316L	ASTM A 479 316L	≤0,03	≤1	≤2	16-18	2-3	10-14	P<0,045	500-700	200	≤ 215HB
Oxidkeramik	OK 1	Al ₂ O ₃	99,7%	Rest	Si O ₂	MgO	Ca O	TiO ₂	Fe ₂ O ₃		≈ 2300 HV
Hardmetall	H 2	WC			97		Co	3			≈ 1500 HV
hard metal	H 3			WC	94		Co	6			≈ 1500 HV
Metal dun	H 12			WC	90,5		Ni Cr	9,5			≈ 1500 HV

Wir bestätigen, dass die unter oben genannter LEWA-Auftragsnr. gelieferten Erzeugnisse, insbesondere die fluidberührten Teile, den in der Bestellung vereinbarten Werkstoffen entsprechen. Die Analyse sowie die mechanischen Eigenschaften sind der Tabelle zu entnehmen. Die entsprechenden Werkszeugnisse nach EN 10204/2.2 bzw. Abnahmeprüfzeugnisse nach EN 10204/3.1 B liegen dem Hersteller vor.

We certify that the goods supplied under above mentioned LEWA order no., especially the wetted parts, are according to the materials as mentioned in the order. The analysis as well as the mechanical properties of the materials used are stated on the above table enclosed. The appropriate material certificates acc. to EN 10204/2.2 respectively acceptance inspection certificates acc. to EN 10204/3.1 B are available at the manufacturer.

Nous confirmons que les produits fournis sous la référence LEWA susmentionnée, notamment les pièces étant en contact avec le fluide, correspondent aux matériaux convenus d'après la commande. L'analyse ainsi que les caractéristiques mécaniques sont représentées dans le tableau des relevés de contrôle suivant la norme allemande EN 10204/2.2 ou bien les certificats de réception suivant EN 10204/3.1B afférents sont présent chez le fabricant.

Datum: 27.11.2009
Date:
Date:

Der Prüfbeauftragte: **H. Reger**
Nominated inspector:
Inspecteur mandaté:



Pump certificates

ASTM A 380-06 Standard Practice for Cleaning, Descaling, and Passivation of Stainless Steel Parts, Equipment, and Systems.

ASTM A 967 Chemical Passivation Treatments for Stainless Steel Parts

ASTM A380 covers recommendations and precautions for cleaning descaling, and passivating of new stainless steel parts, assemblies and installed systems. More in “Surface Cleaning, Finishing, and Coating” *ASM Metals Handbook*.

- Design
- Precleaning
- Descaling
- Cleaning/Passivation
- Inspection



4

3

2

1

REV	DESCRIPTION	DRAWN	DATE
		APPROVED	DATE




UNLESS OTHERWISE SPECIFIED	ORIGINATOR	D. OLIS	10-JUL-2008
	DRAWN	T. HAMERLA	12-MAR-2009
	CHECKED	D. OLIS	12-MAR-2009
	APPROVED	A. ROWE	13-MAR-2009
1. BREAK ALL SHARP EDGES MAX.	USED ON		
2. DO NOT SCALE DRAWING.			
3. DIMENSIONS BASED UPON ASME Y14.5M-1994			
4. MAX. ALL MACH. SURFACES 32	MATERIAL	ULTRA PURE FITTING WITH BCF CONNECTIONS & STAINLESS STEEL	
5. DRAWING UNITS: U.S. INCH			

FERMI NATIONAL ACCELERATOR LABORATORY
 UNITED STATES DEPARTMENT OF ENERGY

SCRF - HIGH PRESSURE RINSE
HPR STATION
PID ANL RM B-101, BLDG 208

SCALE	DRAWING NUMBER	SHEET	REV
NONE	5525.000-MC-457283	1 OF 1	

CREATED WITH : Ideast2NXSeries GROUP: ACCELERATOR MECH. SUPPT.



NOTICE: IMAGE OBTAINED FROM FERMILAB WEB SITE
 This information is provided for REFERENCE use only. It is not for MANUFACTURE, or DESIGN INFORMATION.
 Any information contained in this document represents work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor Universities Research Association, Inc., nor any of their employees or officers, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights.

4

3


2

1




Additional filter was installed before low pressure manifold. No filter discoloration after 95 hours of HPR at 2.5 g/min (14250 gallons at 1350 psi) .

Suspected Contaminant Source - Microbiologically Influenced Corrosion



Simplified diagram showing MIC corrosion site

Microbiologically Influenced Corrosion is a corrosion caused or promoted by microorganisms. It can apply to both metals and non-metallic materials.



Iron-related bacteria



Sulfate Reducing Bacteria

MIC-related bacterial growth typically occurs in systems within specific temperature ranges, depending on the type of bacteria; an “ideal” range is often reported as 4° to 49°C. Bacterial growth typically hibernates below 4°C. Some types of bacteria favor other temperature ranges; for example, most common strains of SRB grow best at 25° to 35°C. A few thermophilic types of SRB grow more efficiently at more than 60°C, and one type is capable of growing at more than 100°C. While MIC more favorably grows in their typical temperature ranges, growth in other temperature ranges should not be discounted. MIC has been found in extremely cold environments such as freezers or piping systems of Alaskan villages north of the Arctic Circle.

Environmental Microbiology Lab test

We have send contaminated and clean filter to EMSL lab for detection of bacteria known to cause or accelerate corrosion in stainless steel.

- **Sulfate Reducing Bacteria** chemically reduce sulfates to sulfides, producing compounds such as hydrogen sulfide (H_2S), or iron sulfide (Fe_2S) in the case of ferrous metals.
- **Iron-related bacteria** are bacteria that derive the energy they need to live and multiply by oxidizing dissolved ferrous iron.
- **Slime-Forming Bacteria** is the name given to bacteria that are able to produce copious amounts of slime. These are commonly seen as condensed cloudy/plate-like growths suspended in the liquid medium, gel-like rings (around the ball) or globular/swirl forms of slime in the basal cone.

Bacteria detection test results



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077 (856) 858-4800

Detection of Iron-Related Bacteria in Bulk Samples with the IRB-BART™ System (EMSL Method: M121)

Lab Sample Number	Client Sample ID	Sample Location	Amount Analyzed	Iron-related Bacteria (Present/Absent)	Potential Population Size (CFU/g)	Identification of Dominant Organism
4135-1	1	Contaminated filter	15mL	Absent		
4135-2	2	Clean filter	15mL	Absent		

Detection of Sulfate-Reducing Bacteria in Bulk Samples with the SRB-BART™ System (EMSL Method: M122)

Lab Sample Number	Client Sample ID	Sample Location	Amount Analyzed	Sulfate-reducing Bacteria (Present/Absent)	Potential Population Size (CFU/g)	Identification of Dominant Organism
4135-1	1	Contaminated filter	15mL	Absent		
4135-2	2	Clean filter	15mL	Absent		

Detection of Slime-Forming Bacteria in Bulk Samples with the SLYM-BART™ System (EMSL Method: M123)

Lab Sample Number	Client Sample ID	Sample Location	Amount Analyzed	Slime-forming Bacteria (Present/Absent)	Potential Population Size (CFU/g)	Identification of Dominant Organism
4135-1	1	Contaminated filter	15mL	Absent		
4135-2	2	Clean filter	15mL	Absent		




EMSL Analytical, Inc.

Basic Material ID Analyses




Stereomicroscope image (10x)



PLM image (150x) of the material from the contaminated filter sample showing color and morphology



Basic Material ID Analyses



Elements:	Weight %	Atomic %
O	30.04	32.93
Na	7.69	5.87
Mg	0.05	0.04
Al	0.27	0.18
Si	0.86	0.54
P	7.32	4.14
S	0.29	0.16
K	2.54	1.14
Cr	2.9	0.98
Fe	13.09	4.11
Ni	0.96	0.29
C	34	49.65


SEM/EDX elemental analysis of the material from the sample filter. The combination of iron (Fe), nickel (Ni) and chromium (Cr) is indicative of stainless steel oxides. The combination of phosphorous (P), sulfur (S), potassium (K), sodium (Na) and Magnesium (Mg) are indicative of salts and other minerals. The combination of aluminum (Al) and silicon (Si) and oxygen (O) may indicate clays or grinding/polishing compounds. The high percentage of carbon (C) may me from a biological source such as bacteria, mold, or algae.

Sample	Description	Analyte	Relative Concentration
1	Contaminated Filter	Inorganic material Salts Stainless steel oxides Organic/biological Unidentified	Major Major Secondary Secondary Trace


Stainless steel residual contaminations

Table 2. Examples of cleaning procedures		
Contamination	Cleaning methods Characterised by medium, temperature, contact time, rinsing pressure, etc.	Extent of residual contamination (Examples)
Polishing compound coverage	Alkaline compound removal through heating HC 500	< 0.5 mg/dm ² Residual compound coverage on refined steel surface
Punching compound coverage	Alkaline compound removal through heating HC 500	< 0.5 mg/dm ² Residual compound coverage on refined steel surface
Drawing compound coverage	Alkaline compound removal through heating HC 500 + Electrochemical polishing HE 111 (Electrochemical removal 5 µm)	< 0.5 mg/dm ² Residual compound coverage on refined steel surface (CFOS application)
Grinding particle	Electrochemical polishing HE 111 (Electrochemical removal 5 µm)	< 10 particles > 1 µm per dm ² Refined steel surface
Residual chlorides	Chemical rinsing HC 1100	< 10 ppm Cl ⁻ , or < 0.1 mg Cl ⁻ /m ²
Fe-oxides	Chemical rinsing HC 700	< 1 ppm Fe
Fe-oxides as red layer	Chemical rinsing HC 1106	< 1 ppm Fe
Fe-sulphates	Chemical rinsing HC 1106/HC 1100	< 1 ppb S


Old manifolds internal surface inspection




Weld quality not acceptable, pits, Heat tint, rough surface.




**Pitting corrosion or Weld Metal Defect
(C.Cooper)**





**Pitting corrosion or Weld Metal Defect
(C.Cooper)**



Pitting corrosion or Weld Metal Defect (C.Cooper)



SEM Image of Stainless Steel Corrosion Pit from PMET's Materials Characterization Laboratory



Spectrum	In stats.	C	O	Cr	Fe	Ni	Mo	Total
Spectrum 1	Yes	2.51	1.4	20.2	63.2	10.5	2.3	100
Spectrum 2	Yes	4.22	3.2	19.2	62.9	10.5		100
Max.		4.22	3.2	20.2	63.2	10.5	2.3	
Min.		2.51	1.4	19.2	62.9	10.5	0	


S	Cl	Cr	Fe	Zn
3.80%	1.10%	3.40%	89.50%	2.10%

EDX Analysis of Corrosion
 Pit from PMET's Materials
 Characterization Laboratory

EDS Analyses of Argonne
 manifold defect done by C.Cooper


Control of passive layer

Renewable contamination source




Change / Mutation of the passive layer:

The well known problem of the mutation of an ideal corrosion resistant passive layer (chrome oxide primary layer) in conjunction with medias as in WFI systems (austenite stainless steel 316L, or similar stainless steel alloys) into an increasingly metal oxident secondary layer expressed in the so-called „Rouge-Effect“ with forming of heavy-metal-oxide particles which detach from the surface by occurring flow effects.



- Starting point is a bright virgin (metal clean/electrochemically polished) pipe surface. Display is on the GREEN.
- Indication of passive layer reduction. Display switches to GREEN 2.
- First light change in surface colour – ROUGE – starts. Display goes to YELLOW.
- With increasing „Rouge“-effect and the risk of Rouge particles coming off from the stainless steel surface, the alert grade is increasing, as well. Display switches to YELLOW 2.
- Display jumps to RED. The De-Rouging operation must be planned in Time.



High Purity Systems Cleaning and Passivation

SUMMARY:

- Rig system and fill with high purity water;
- Establish circulation and inspect for system integrity;
- Formulate cleaning chemistry;
- Circulate cleaning chemistry at temperature;
- Adjust pH of cleaning chemistry;
- Drain and rinse system with high purity water;
- Fill system with high purity water and formulate passivation chemistry;
- Circulate passivation chemistry at temperature;
- Adjust pH of passivation chemistry;
- Drain and rinse system with high purity water to achieve conductivity parity;
- Perform final inspection and return system to starting configuration.



Benefits of Passivation


Average composition of
316L stainless steel

ELEMENT:	CONCENTRATION:
IRON	67.0% - 69.0%
CHROMIUM	16.0% - 18.0%
NICKEL	10.0% - 14.0%
MOLYBDENUM	2.0% - 3.0%
MANGANESE	2.0% maximum
SILICON	1.0% maximum
PHOSPHORUS	0.04% maximum
SULFUR	0.03% maximum
CARBON	0.03% maximum

Ratio of chrome to iron in the base metal is 0.24. By chemically treating the surface of the stainless steel, such that iron is removed, then the ratio of chrome to iron is increased.

With a good passivation procedure, elemental chrome to iron ratios in the range of 0.75 to 2.0 can be attained. Reducing iron content at the surface, while leaving chrome, results in a "chromium rich" surface, which is less likely to form corrosion products. The "chromium rich" or passive layer is found to be extremely thin - not more than 50 angstroms in depth.

Stainless steel corrosion in High Purity Water Systems



Stainless steel corrosion in Argonne HPR system



Current maintenance procedure:

1. Sanitize with 1 – 2% Minncare solution every 12 month
2. Replace first filter every month, second filter every 6 month.
3. Rinse with DI water

MINNCARE® COLD STERILANT (EPA Reg. No. 52252-4)

Component	CAS #	Amount (percentage by Weight)	PEL
Hydrogen Peroxide	7722-84-1	22.0%	1 ppm
Peracetic Acid	79-21-0	4.5%	NE
Acetic Acid	64-19-7	-	10 ppm
Water	7732-18-5	-	NE

Next steps

- Inspect internal surfaces of pump heads and manifolds at Argonne for signs of corrosion or surface contamination.
- Clean and passivate both manifolds and High Pressure pump heads on-site or off-site if needed.
- Coat internal surfaces with Tantaline solution (surface alloy technology that create an extremely rugged, uniform, inert and corrosion resistant tantalum surface).*

*No indication that HPR system is degrading cavity performance.